

Permit Number: PAN-010150

Operator: Conrad (Hawarden) Limited

Facility: Hawarden Power
Generation Plant

Form Number: Air1

Reporting of emissions to air for the period from **28/01/2021** to **28/01/2024**

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
A1	Oxides of Nitrogen (NO and NO ₂ expressed as NO ₂)	95 mg/m ³	Periodic (average over one hour)	91 mg/m ³	MCERTS BS EN 14792	19/12/2023 11:28- 12:28	± 1.8
	Carbon Monoxide	No limit set		367 mg/m ³	MCERTS BS EN 15058		± 1.4

1. The result given is the average maximum value across two sampling points, Bank A and Bank B, obtained during the reporting period, expressed in the same terms as the emission limit value.
2. Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Environment Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.
3. For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
4. The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed 

Date...29/12/2023.....

(Authorised to sign as representative of Operator)