

Permit Number: BX8289IW

Operator: Princes Limited

Facility: Soft Drinks Site – Cardiff

Form Number: Air1 / 10/08/2022

Reporting of emissions to air for the period from 15/07/2021 to 15/07/2021

Emission Point	Substance / Parameter	Emission		Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
		Limit Value						
A1	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	250 mg/m ³ ^[5]		Periodic	81.82 mg/m3	BS EN 14792:2017	15/07/21 13:31 – 14:31	3%
A1	Carbon monoxide	No limit set		Periodic	3.15 mg/m3	BS EN 15058:2017	15/07/21 13:31 – 14:31	3%
A2	Oxides of nitrogen (NO and NO ₂ expressed as NO ₂)	100 mg/m ³		Periodic	78.07mg/m3	BS EN 14792:2017	15/07/21 11:29 -12:29	3%
A2	Carbon monoxide	No limit set		Periodic	3.54mg/m3	BS EN 15058:2017	15/07/21 11:29 -12:29	3%

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

[5] Limit applies from 01/01/2030 or other date as notified by Natural Resources Wales in writing.

SignedJ.Powell.....
(Authorised to sign as representative of Operator)

Date.....17/04/2023.....