

Compliance Assessment Report CAR_NRW0042284

Permit being assessed: AN0247201

For: LLWYNON WATER TREATMENT PLANT, held by DWR CYMRU CYFYNGEDIG

At: Llwynon, Cwmtaff, Merthyr Tydfil, CF48 2HS.

Type of assessment carried out: Check Monitoring/Sampling, Reason: Routine.

On 05/09/2023.

Parts of permit assessed: 3.1 Emissions to water

NRW Lead Officer: Paul Latham.

Report sent to: CARS@dwrcymru.com, CARS@dwrcymru.com, on 13/03/2024.

1. Summary of our findings (full details in section 4)

Part of permitted activity assessed (criteria)	Assessment result	Permit condition
WQ-C1 - Emissions and monitoring - Emissions to water	C2 Significant	3.1 Emissions to water 3.1.1 The limits given in schedule 3 table S3.1 shall not be exceeded.

Result types are explained in more detail in the 'Important Information' section below.

2. What action is required?

Criteria	Action needed	Complete by
WQ-C1	Explain the root cause of the exceedances to include length of time of non compliant discharge and actions taken to return asset to compliance.	Already completed

Action criteria codes are listed in the 'Important information' section below.

3. What will happen next?

Any non-compliance we have identified and recorded on this form is an offence. It can result in criminal prosecution and/or suspension or revocation of your permit.

You are non-compliant with your permit.

At this time, we are issuing you with a warning for the non-compliance recorded above. Warnings may influence future enforcement response for continued or further non-compliance.

This statement does not stop us from taking additional enforcement action if further relevant information comes to light or offences continue.

4. Details of our assessment

Re-issuing compliance form to escalate category based on legacy guidance OI 238_03, a result of 2.0 is more than twice any absolute (that is, non-sanitary) limit, but not MORE THAN 4 times the limit, hence the guidance recommends a Cat 2.

OSM exceedance notification for Llwyn On WTW

The Total Chlorine sample result is the second sample above agreed limit in a series of samples taken in any period of 12 consecutive months.

Could DCWW please explain what was the root cause of the elevated result, and what was done to bring the asset back within compliance?

Could this information be sent before 09/10/2023 to paul.latham@naturalresourceswales.gov.uk

Llwyn-On WTW																																																																																																															
AN0247201																																																																																																															
68069																																																																																																															
12/07/2023																																																																																																															
Total Available Chlorine																																																																																																															
Yes ☒ No ☐																																																																																																															
0.20 mg/l																																																																																																															
0.05 mg/l MAX																																																																																																															
Sample checked with the laboratory and result confirmed. This is the 2nd exceedance for Total Chlorine at this site within the last 12-month period: <table border="1"> <thead> <tr> <th colspan="5"></th> <th colspan="3">912</th> </tr> <tr> <th colspan="5"></th> <th colspan="3">OSM Total Chlorine</th> </tr> <tr> <th colspan="5"></th> <th colspan="3">mg/L</th> </tr> <tr> <th>SPT NO</th> <th>SAMPLE POINT</th> <th>SAMPLE DATE/TIME</th> <th>LAB REF NO</th> <th>PC</th> <th>Result Val</th> <th>Result Qual</th> <th>Result Status</th> </tr> </thead> <tbody> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>12/Jul/23 10:06</td> <td>7651007</td> <td>SM</td> <td>0.2</td> <td></td> <td>A</td> </tr> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>27/Jun/23 10:13</td> <td>7635343</td> <td>SM</td> <td>0.05</td> <td><</td> <td>A</td> </tr> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>21/Apr/23 09:35</td> <td>7573760</td> <td>SM</td> <td>0.07</td> <td></td> <td>A</td> </tr> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>23/Feb/23 10:23</td> <td>7523143</td> <td>SM</td> <td>0.05</td> <td><</td> <td>A</td> </tr> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>21/Dec/22 10:09</td> <td>7462601</td> <td>SM</td> <td>No Flow Event</td> <td></td> <td></td> </tr> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>16/Nov/22 12:03</td> <td>7433857</td> <td>SM</td> <td>0.05</td> <td><</td> <td>A</td> </tr> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>27/Sep/22 09:58</td> <td>7388486</td> <td>SM</td> <td>No Flow Event</td> <td></td> <td></td> </tr> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>13/Sep/22 10:30</td> <td>7375316</td> <td>SM</td> <td>No Flow Event</td> <td></td> <td></td> </tr> <tr> <td>68069</td> <td>Llwyn-On WTW</td> <td>19/Aug/22 12:12</td> <td>7352107</td> <td>SM</td> <td>No Flow Event</td> <td></td> <td></td> </tr> </tbody> </table> The sample result is greater than the Max consent limit. <u>Therefore</u> this result is a failure. Name: Kelly Rowe Role: Catchment Manager (SE Catchment, WW Services)													912								OSM Total Chlorine								mg/L			SPT NO	SAMPLE POINT	SAMPLE DATE/TIME	LAB REF NO	PC	Result Val	Result Qual	Result Status	68069	Llwyn-On WTW	12/Jul/23 10:06	7651007	SM	0.2		A	68069	Llwyn-On WTW	27/Jun/23 10:13	7635343	SM	0.05	<	A	68069	Llwyn-On WTW	21/Apr/23 09:35	7573760	SM	0.07		A	68069	Llwyn-On WTW	23/Feb/23 10:23	7523143	SM	0.05	<	A	68069	Llwyn-On WTW	21/Dec/22 10:09	7462601	SM	No Flow Event			68069	Llwyn-On WTW	16/Nov/22 12:03	7433857	SM	0.05	<	A	68069	Llwyn-On WTW	27/Sep/22 09:58	7388486	SM	No Flow Event			68069	Llwyn-On WTW	13/Sep/22 10:30	7375316	SM	No Flow Event			68069	Llwyn-On WTW	19/Aug/22 12:12	7352107	SM	No Flow Event		
					912																																																																																																										
					OSM Total Chlorine																																																																																																										
					mg/L																																																																																																										
SPT NO	SAMPLE POINT	SAMPLE DATE/TIME	LAB REF NO	PC	Result Val	Result Qual	Result Status																																																																																																								
68069	Llwyn-On WTW	12/Jul/23 10:06	7651007	SM	0.2		A																																																																																																								
68069	Llwyn-On WTW	27/Jun/23 10:13	7635343	SM	0.05	<	A																																																																																																								
68069	Llwyn-On WTW	21/Apr/23 09:35	7573760	SM	0.07		A																																																																																																								
68069	Llwyn-On WTW	23/Feb/23 10:23	7523143	SM	0.05	<	A																																																																																																								
68069	Llwyn-On WTW	21/Dec/22 10:09	7462601	SM	No Flow Event																																																																																																										
68069	Llwyn-On WTW	16/Nov/22 12:03	7433857	SM	0.05	<	A																																																																																																								
68069	Llwyn-On WTW	27/Sep/22 09:58	7388486	SM	No Flow Event																																																																																																										
68069	Llwyn-On WTW	13/Sep/22 10:30	7375316	SM	No Flow Event																																																																																																										
68069	Llwyn-On WTW	19/Aug/22 12:12	7352107	SM	No Flow Event																																																																																																										

--

If you have any queries about this report, or to discuss completion of any actions, please contact the NRW Officer named above.

Important information

Legal status of this report

Your permit is issued to you under the Environmental Permitting Regulations. You have a responsibility to comply with the conditions of your permit and prevent pollution/harm to the environment. You must also ensure that you comply with any other relevant legislation that may apply to your site's operations.

This report explains the findings of our assessment and any action you are required to take. We categorise non-compliance using our guidance for assessing non-compliance at regulated sites.

When we find potential non-compliance/s we will normally give you advice on how to maintain compliance.

To correct non-compliance, we may:

- require you to take specific actions
- issue a notice
- review the conditions of your permit.

Any advice and guidance we give will be without prejudice to any other enforcement response that we consider may be required.

Assessment results and non-compliance categories (used in section 1):

Assessment result	Description
Assessed (A)	Assessed or assessed in part, no evidence of non-compliance found
Action only (X)	Action only relating to the activity assessment
Ongoing (O)	Ongoing non-compliance, not scored

Non-compliance category	Description
C1 Major	Potential to have a major, serious, persistent and/or extensive impact or effect on the environment, people and/or property
C2 Significant	Potential to have a significant impact or effect on the environment, people and/or property
C3 Minor	Potential to have a minor or minimal impact or effect on the environment, people and/or property
C4 No environmental impact	Non-compliance at a regulated site that cannot foreseeably have any impact on the environment, people and/or property

If your assessment result in Section 1 is suspended, what does this mean?

In line with our guidance, we may suspend non-compliance for up to six months to allow time for remedial action to be taken. These will be re-instated if the action is not completed.

Full list of water quality action criteria (used in section 1 and 2):**WQ A: Management**

- WQ-A1 General management

WQ B: Operations

- WQ-B1 Permitted activities
- WQ-B2 The site
- WQ-B3 Operating techniques
- WQ-B4 Improvement programme
- WQ-B5 Pre-operational conditions

WQ C: Emissions and monitoring

- WQ-C1 Emissions to water
- WQ-C2 Emissions to land
- WQ-C3 Emissions of substances not controlled by emission limits
- WQ-C4 Installation of monitoring boreholes

WQ D: Information

- WQ-D1 Records
- WQ-D2 Reporting
- WQ-D3 Notifications

Enforcement response

Any permit condition non-compliance is an offence and we may take legal action against you. Action we take can include prosecution, serving a notice on you and/or suspension or revocation of your permit. See our Enforcement and Sanctions Guidance for further information.

Data protection notice

You should make sure that anyone named in this report knows that the information it contains will be processed by Natural Resources Wales to fulfil its regulatory and monitoring functions and to maintain the relevant public register(s).

We may also use and/or disclose the report in connection with:

- offering or providing you with our literature or services relating to environmental matters
- consulting with the public, public bodies and other organisations (e.g. Health and Safety Executive, local authorities) on environmental issues
- carrying out statistical analysis, research and development on environmental issues
- providing public register information to enquirers
- investigating possible breaches of environmental law
- assessing customer service satisfaction and improving our service
- Freedom of Information Act or Environmental Information Regulations requests.

We may also pass it on to our agents or representatives to do these things on our behalf.

Disclosure of information – this report will be available to view on-line

If you think this report contains commercially confidential information that should not be placed on our public register, you must contact your local Natural Resources Wales office within **fifteen working days** of receiving this report, using the contact details in the accompanying email or letter. You must give a full explanation of why it should not be

added to our public register, including specifying which information is commercially confidential. We will assess your request and respond to you within 20 working days to let you know if we agree to your request.

What do I do if I disagree with the report or have a complaint?

If you disagree with this compliance assessment report, you should contact the lead officer without delay to discuss your concerns.

If you are unable to resolve the issue with the lead officer or their line manager you should contact our Customer Contact team on 0300 065 3000 (Monday to Friday 08:00 – 18:00), or email enquiries@naturalresourceswales.gov.uk for details of how to raise your dispute further through our Complaints and Commendations procedure.

If you are dissatisfied with our response, you can contact the Public Services Ombudsman for Wales by phone on 0300 7900203 or by email at ask@ombudsman.wales

Welsh Language Standards

We are committed to establishing Natural Resources Wales as a naturally bilingual organisation. We will provide compliance reports in your preferred language.