

Schedule 1 – 5.1.1 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	W1 Effluent
Time and date of the emission:	The week leading up to: w/e 18/08/2019

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
PCP	Discharge to Estuary	262.7 g/wk Vs 250 g/wk mass limit	N/A

Measures taken, or intended to be taken, to stop the emission:	There was a slight delay in completion of the weekly analysis, but subsequent samples indicate elevated levels, but within compliance Options are being reviewed to reconfigure the reed-beds treatment system (currently in 'establishment' phase) to reduce the risk of untreated groundwater findings its way in to the site effluent system, which seems to occur following periods of rainfall Additional information to follow in Part B
---	---

* Signed: 

Date: 22/08/2019

* authorised to sign on behalf of Solutia UK Ltd