

Date of form 13/10/14

NOT YET COMMISSIONED

Date of form 13/10/14

NOT YET COMMISSIONED

Date of form 13/10/14

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: September 2019

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.6	1.8	19/07/2019
Suspended Solids mg/l	50	2.0	8.0	19/07/2019
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	15/08/2019
Suspended Solids mg/l	50	4.0	6.0	15/08/2019
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	19/09/2019
Suspended Solids mg/l	50	6.0	5.0	19/09/2019

* Sample compromised at the laboratory

Signed on behalf of the Operator *H. May*

Date *10.10.19*

Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: September 2019

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.3	7.0	8.44	9.1
Total suspended solids mg/l	600	6	90.4	268	400
Total chemical oxygen demand (COD) mg/l	3600	284	662.3	1259.5	1320
Free or emulsified grease or oil mg/l	100	4.52	12.3	19.855	22
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.1	0.21	0.24
Dissolved oxygen mg/l	-	0.5	0.6	1.3	1.3
Ammoniacal nitrogen as N mg/l	30	11.6	39.5	95.48	126
Daily flow m ³ /day	800	23.0	575.5	799.4	855.3
Maximum flow m ³ /h	34	1.0	17.9	33.3	35.6

Signed on behalf of the Operator *H. Mj.*Date 10.10.19