

CONSENT NO.	CG0138701
-------------	-----------



WATER RESOURCES ACT 1991
SECTION 88 - SCHEDULE 10

VARIATION OF CONSENT TO DISCHARGE

In pursuance of an application by the consent holder for variation of consent, the **ENVIRONMENT AGENCY** ("The Agency") in pursuance of its powers under the Water Resources Act 1991 **HEREBY VARIES ITS CONSENT** to the making of a discharge **OF SEWAGE EFFLUENT** as follows:

With respect to Consent No. CG0138701 issued on the 23rd November 1992 and subsequent Notice of Modification issued on the 31st March 2005

FROM: TREFOR WASTEWATER TREATMENT WORKS

AT: TREFOR, CAERNARFON, GWYNEDD LL54 5LB

TO: COASTAL WATERS

HEREAFTER SUBJECT TO the conditions set out in the following schedule(s).

Secondary Treated Sewage Effluent

Schedule No. CG0138701 01

UWWT Regulations 1994

Schedule No. CG0138701 01/U

Subject to the provisions of Paragraphs 7 and 8 of Schedule 10 of the Water Resources Act 1991, no notice shall be served by the Agency, which alters the effect of variations made to this consent, without the agreement in writing of the consent holder, during a period of 4 years from the date this variation is issued.

This variation of consent is issued on the 19th day of December 2005
This variation of consent takes effect on the 31st day of December 2005

Signed John Williams

IWAN WILLIAMS

Regulatory Water Quality Team Leader

Asiantaeth yr Amgylchedd Cymru
Ffordd Caer, Bwcle, Sir Fflint CH7 3AJ. Ffôn 08708 506506, Ffacs 01244 550144

Environment Agency Wales
Chester Road, Buckley, Flintshire CH7 3AJ. Tel 08708 506506. Fax 01244 550144



CONSENT NO.	CG0138701
SCHEDULE NO.	CG0138701 01
DATE ISSUED	19th December 2005

CONDITIONS OF CONSENT TO DISCHARGE

Secondary Treated Sewage Effluent ("the Discharge")

FROM: Trefor Wastewater Treatment Works, Trefor, Caernarfon,
Gwynedd LL54 5LB

NATURE

1. The Discharge shall consist solely of secondary treated sewage effluent.

LOCATION

2. The Discharge shall be made in the manner and at the place specified as:
 - (a) discharging via a 225 millimetre diameter pipe;
 - (b) discharging to coastal waters;
 - (c) at National Grid Reference SH 37277 47528;
 - (d) shown marked 'Consent Point' on Plan CG0138701 attached as Annex 2.

SAMPLE POINT

3. An appropriately labelled sample point shall be provided and maintained at National Grid Reference SH 37173 47092, as shown marked 'Discharge Sample point' on the Plan CG0138701 attached as Annex 2 or some other point as agreed in writing with the Agency, so that a representative spot sample of the Discharge may be obtained. The Consent Holder shall ensure that all constituents of the Discharge pass through the said sampling point at all times and in any legal proceedings it shall, for the purposes of Section 10 of the Rivers (Prevention of Pollution) Act 1961, be presumed, until the contrary is shown, that any sample of the Discharge taken at the said sampling point is a sample of what was being discharged into controlled waters.



CONSENT NO.	CG0138701
SCHEDULE NO.	CG0138701 01

VOLUME

4. The volume of the Discharge shall not exceed 571.3 cubic metres per day.
5. The Dry Weather Flow of the Discharge shall not exceed 275.1 cubic metres per day.

For the purpose of this condition Dry Weather Flow shall mean the average daily flow to the treatment works during seven consecutive days without rain (excluding a period which includes public holidays) following seven days during which the rainfall did not exceed 0.25 millimetres on any one day.

6. The rate of discharge shall not exceed 6.6 litres per second.

FLOW MEASUREMENT

7. A continuous flow measurement and recording system, to a specification provided by the Agency, shall be provided and operated to record the total daily volume, and the instantaneous or 15-minute integrated flow every 15 minutes of sewage through the treatment works. An on-site visual display from which instantaneous or 15-minute integrated flow readings can be readily obtained by the Agency shall be provided and operated. The Consent Holder shall hold records of the flow readings.
8. As soon as practicable after completion of the flow system installation and subsequently on the expiry of any certificate issued, the Consent Holder shall employ an independent expert to certify that the installation and its quality management system complies with the Agency's specification. The independent expert shall be accredited to a competency scheme approved by the Agency. A copy of the certificate shall be sent to the Agency and the certifier's report shall be provided to the Agency on request. If a certificate issued for a flow system has no expiry date included then the certificate shall be deemed to expire five years after the issue date of the certificate.
9. The Consent Holder shall produce and maintain a documented quality management system, approved by the independent expert and to the satisfaction of the Agency, specifying procedures for the calibration, operation and maintenance of the flow measurement equipment. The flow measurement equipment shall be calibrated, operated and maintained by the Consent Holder in accordance with the provisions of the QMS. The Consent Holder shall keep a record of these procedures available for inspection by the Agency and provide a copy to the Agency on request.



CONSENT NO.	CG0138701
SCHEDULE NO.	CG0138701 01

10. The Consent Holder shall record all failures of the continuous flow measurement system and any other breaks in the flow record. The reasons for all significant failures and breaks, which lead to missing or suspect data, and all steps taken to prevent a re-occurrence shall be recorded and details shall be provided to the Agency on request. A failure or break is significant for the purposes of this condition if it prevents the calculation of the total daily volume to the required level of uncertainty. The Consent Holder shall ensure that as far as possible the recorder remains fully operational at all times. Any failures shall be remedied as soon as possible.
11. Records of the flow readings or the reasons for any breaks in the record, as described in condition 10 above, shall be provided to the Agency when requested, in a format specified by the Agency.
12. Flows of sewage through the treatment works shall be measured at the inlet works NGR SH 37168 47075, or such other point(s) as is/are agreed by the Agency.

COMPOSITION

13. (a) Subject to paragraph (b) below, the Discharge shall not contain more than;
 - (i) 40 milligrammes per litre of biochemical oxygen demand (measured after 5 days at 20⁰ C with nitrification suppressed by the addition of allyl-thiourea)
 - (ii) 60 milligrammes per litre of suspended solids (measured after drying at 105⁰C);
- (b) The limit for any of the relevant parameters set out in paragraph (a) above may be exceeded where, in any series of samples of the Discharge taken at regular but randomised intervals in any period of twelve consecutive months as listed in Column 1 of the table at Annex 1 to this consent, no more than the relevant number of samples, as listed in Column 2 of the said table, exceed the applicable limit for that relevant parameter.



CONSENT NO.	CG0138701
SCHEDULE NO.	CG0138701 01

WORKS OPERATION

14. The works shall be operated and the effluent shall be treated in a manner which, so far as reasonably practicable, minimises the polluting effects of the discharge made from the works on controlled waters.

This condition does not require –

- (a) any higher standard to be achieved in relation to any characteristic of the discharge which is specifically regulated by Condition 13 than is required by that condition;
- (b) any alteration of the works or a change in the type of treatment used.

UNUSUAL WEATHER

15. (a) No sample of the discharge, taken at a time when unusual weather conditions are adversely affecting the operation of the sewage treatment works, shall be taken into account in deciding whether or not conditions 13 and 14 of this consent schedule have been complied with.
- (b) For the purpose of this condition “unusual weather conditions” shall include:
- (i) low ambient temperatures as evidenced by effluent temperatures of 5°C or less, or by the freezing of mechanical equipment in the works;
 - (ii) significant snow deposits;
 - (iii) tidal or fluvial flooding;
 - (iv) weather conditions causing unforeseen loss of power supply to the sewage treatment which could not be ameliorated by the reasonable provision and operation of standby generation facilities.



CONSENT NO.	CG0138701
SCHEDULE NO.	CG0138701 01

- (c) On any occasion where unusual weather conditions adversely affect the operation of the sewage treatment works, the Consent Holder shall use its best endeavours to mitigate that adverse affect.
- (d) For a sample of the discharge to be considered for the purposes of (a) above, the Consent Holder shall notify the Agency by telefax or telephone as soon as unusual weather conditions are known to have adversely affected operations and shall confirm the circumstances in writing as soon as possible thereafter (and in any event within 14 days of the occurrence of such conditions). That notification shall include a full description of the unusual weather conditions and their impact on the operation of the works.

RECORDING AND REPORTING

- 16. (a) The Consent Holder shall establish and operate a documented maintenance programme and record all non-routine actions undertaken that may have adversely affected effluent quality. Copies of the programme shall be made available for inspection by the Agency's officers at all reasonable times.
- (b) On request the Consent Holder shall supply the Agency with a written report on the maintenance and all non-routine actions that may have adversely affected effluent quality.

SUBSTANTIAL CHANGE

- 17. (a) A discharge shall not be made from the works if it would cause a significant increase in the polluting effects of the discharge on controlled waters as a result of a new or altered discharge of trade effluent into the works.
- (b) A discharge of trade effluent into the works is new if -
 - (i) it is made by the sewerage undertaker and is of a kind not made into the works by the undertaker immediately before the date of effect of this consent; or
 - (ii) it is made by a third party and the discharge is authorised on or after that date.



CONSENT NO.	CG0138701
SCHEDULE NO.	CG0138701 01

- (c) A discharge of trade effluent into the works is altered if -
- (i) it is made by the sewerage undertaker and its composition or quantity changes significantly on or after date of variation of this consent ; or
 - (ii) it is made by a third party and the alteration of the discharge is authorised on or after that date.
- (d) An increase in the polluting effects of the discharge on controlled waters is not significant for the purposes of this condition if it relates to any characteristics of the discharge which are specifically regulated by condition 13 of this consent schedule but it may be significant if it is caused by a change in some other characteristic of the discharge.
- (e) For the purposes of this condition “trade effluent” means –
- (i) any discharge by the sewerage undertaker other than
 - (1) domestic sewage from premises connected directly or indirectly to the works; or
 - (2) surface water run-off;
 - (ii) any discharge by a third party which is authorised under Chapter III of Part IV of the Water Industry Act 1991 or which is only accepted as a result of a contract with the sewerage undertaker.

UNAUTHORISED DISCHARGE

18. (a) A discharge made from the works shall not contain any poisonous, noxious or polluting matter or solid waste matter which is attributable to any unauthorised discharge into the works.
- (b) A discharge into the works is unauthorised if it is made by a third party and either there is no obligation to receive it or conditions subject to which there is an obligation to receive it are not observed.
- (c) Nothing in this, or any other, condition of this consent prevents anyone from relying on any defence available to them under Section 87 of the Water Resources Act 1991.

creu lle gwell
creating a better place



Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

CONSENT NO.	CG0138701
SCHEDULE NO.	CG0138701 01

START DATE

19. Until the Discharge is permitted under the terms of this consent, the quality of the effluent from Trefor Sewage Treatment Works shall be controlled under the terms of the consent issued on 23rd November 1992.
There shall be no discharge under the terms of this consent until the 31st December 2005 or the end of commissioning of the works whichever is the sooner. The Consent Holder shall give the Agency at least 28 days written notice before making the discharge.



CONSENT NO.	CG0138701
SCHEDULE NO.	CG0138701 01/U
DATE ISSUED	19 th December 2005

CONDITIONS OF CONSENT TO DISCHARGE

Urban Waste Water Treatment Regulations 1994 ("the Discharge")

**FROM: Trefor Wastewater Treatment Works, Trefor, Caernarfon,
Gwynedd LL54 5LB**

- U0** (a) The Consent Holder shall comply with the Urban Waste Water Treatment (England and Wales) Regulations 1994 ("the Regulations").
- (b) For the purpose of condition U1 below, interpretations and references to a numbered regulation or Schedule shall have the meaning as in the Regulations, unless otherwise indicated.
- U1** (a) The Discharge derives from an agglomeration with a population equivalent of less 2,000 discharging to coastal waters.
- (b) The Consent Holder shall inform the Agency in writing of any change, or proposed change, to the population equivalent such as would make a material change to the application of the Regulations and shall, on request, inform the Agency in writing of the actual population equivalent.
- (c) The Discharge shall be subject to Regulation 5(7) and satisfy the requirements of Regulation 5(8)(a).

creu lle gwell
creating a better place



Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

CONSENT NO.	CG0138701
-------------	-----------

ANNEX 1

TABLE

Column 1

Number of samples
taken in any period
of 12 months

Column 2

Maximum number of
samples permitted to
exceed limit for given
determinand

4-7	1
8-16	2
17-28	3
29-40	4
41-53	5
54-67	6
68-81	7
82-95	8
96-110	9
111-125	10
126-140	11
141-155	12
156-171	13
172-187	14
188-203	15
204-219	16
220-235	17
236-251	18
252-268	19
269-284	20
285-300	21
301-317	22
318-334	23
335-350	24
351-365	25

creu lle gwell
creating a better place




Asiantaeth yr
Amgylchedd Cymru
Environment
Agency Wales

CONSENT NO.	CG0138701
-------------	-----------

ANNEX 2

PLAN No. CG0138701



NOT TO SCALE