

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951

(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)

AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

No. 876A-B-C-D
CV/37/11A

CAT. NO. R.B.12 SHAW & SONS LTD., FAYRER LANE, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES	
Conditions come into force as from date of initial discharge.	Gwyrfa Rural District Council, Cwellyn, Caernarvon. Nantlle Valley Sewerage and Sewage Disposal Scheme.	
USE OF NEW OR ALTERED OUTLET		DISCHARGE OF TRADE OR SEWAGE EFFLUENT
<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) PRECISE LOCATION OF OUTLET S.O. No. 1 Approx. Grid Ref. SH 470522 } River Llyfni. S.O. No. 2 Approx. Grid Ref. SH 471525 } S.O. No. 3 Approx. Grid Ref. SH 484527 - Unnamed tributary of River Llyfni S.O. No. 4 Approx. Grid Ref. SH 488527 - Unnamed tributary of River Llyfni. S.O. No. 5 Approx. Grid Ref. SH 512532 - Llyn Nantlle Uchaf.</p> <p>(ii) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE)</p> <p>(iii) USE OF OUTLET Storm Sewage</p> <p>(iv) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES</p>		<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(i) NATURE AND COMPOSITION OF DISCHARGE The discharges being adequately screened so as to prevent the discharge of solid matter.</p> <p>XXXXXXXXXXXXXXXXXXXX The weir settings being such as to overflows only when the folws exceed:- S.O. No. 1 - 1.080m³/day (9 times d.w.f.) S.O. No. 2 - 3,780m³/day (8 times d.w.f.) (iii) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES S.O. No. 3 - 76m³/day (9 times d.w.f.) S.O. No. 4 - 138m³/day (9 times d.w.f.) S.O. No. 5 - 40m³/day (11 times d.w.f.) XXXXXXXXXXXXXXXXXXXX</p> <p>(iv) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S.5(2) OF 1961 ACT 1st August, 1976.</p>
REMARKS-		REMARKS-

C.203/8. AJ/AL.

28th February, 1974.

Dear Sir,

Rivers (Prevention of Pollution) Act 1951
Section 7

With reference to your application of 12th February, 1974, the Gwynedd River Authority, in pursuance of their powers under the above Act, hereby consent to the bringing into use of new outlets for the discharge of storm sewage (screened) and the making of new discharges of storm sewage into the River Llyfni, tributaries and Llyn Pantlle Uchaf at approximately Grid Ref. SH 470522, SH 471525, SH 484527, SH 488527, SH 512532 respectively in accordance with the plans submitted and subject to the following conditions:-

- S.O. No. 1 River Llyfni left bank at Llanilyfni approximately Grid Ref. SH 470522 when flows exceed 1080m³/day (240,000 galls.) (approx. 9 x D.W.F.)
- S.O. No. 2 River Llyfni right bank at Penygroes approximately Grid Ref. SH 471525 when flows exceed 3,780m³/day (832,000 galls.) (approx. 8 x D.W.F.).
- S.O. No. 3 Un-named tributary on right bank of River Llyfni near Telysarn at approx. Grid Ref. SH 484527 when flows exceed 763m³/day (168,000 galls.) (approx. 9 x D.W.F.)
- S.O. No. 4 Un-named tributary on right bank of River Llyfni downstream of road bridge, Telysarn, Grid Ref. SH 488527 when flows exceed 1580m³/day (304,000 galls.) approx. 9 x D.W.F.).
- S.O. No. 5 Llyn Pantlle Uchaf on right bank upstream of roadbridge, Grid Ref. SH 512532 when flows exceed 403m³/day (88,900 galls.) (approx. 11 x D.W.F.).

Subject to the discharges being screened or suitably baffled to prevent the discharge of solid matter, and restricted to those flows in excess of the figures quoted above for each storm overflow.

The terms of this consent will not, without the consent in writing of the person to whom this consent is given (or his successor), be altered before the expiration of the period ending with the 1st day of August, 1976.

- (a) The outlets shall be so constructed and maintained that samples may be readily taken.
- (b) The outlets shall be used for the discharge of storm sewage only.

The Clerk,
Gwynedd Rural District
Council,
Cwellyn,
Llanberis Road,
CAERNARVON.

Yours faithfully,



Clerk of the Authority