

Schedule 5 Notification

PART B

Permit Number:	BR9715IB
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Site Effluent Discharge W2
Time and date of the emission:	04/12/23, 14:45 – 18:45

Any more accurate information on the matters for notification under Part A	As per the Part A Notification, a discharge of surface-water occurred during the 'cease discharge' period at the time & date specified above Analysis of the discharged water was conducted (a composite sample for the day in question), and all parameters (aside from Cd which has a longer lead time for analysis results) were in compliance with the W2 specified limits in Permit Table S3.3.
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Action items: • Confirm the Cd concentration once analysis results received from external laboratory • Review whether there are additional measures that can be taken (e.g. use of alternative storages) to help prevent a similar cease discharge event during extreme rainfall conditions
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	None proposed
The dates of any unauthorised emissions from the installation in the preceding 24 months	04/12/2023 - Effluent Cease Discharge [This Notification] 17/11/2023 - Effluent Pipeline Offsite 13/10/2023 - Benzene Release to Separator 15/09/2023 - Boiler 16 CO 29/08/2023 - Effluent Circulation Pipeline Leak

	06/09/2023 - Formalin in Effluent 06/02/2023 - Dequest Amino 24/11/2022 - Effluent Cease Discharge 14/07/2022 - Effluent Hg 07/03/2022 - Biphenyl Tanker
--	--

*** Signed:**



Date: 06/12/2023

* authorised to sign on behalf of Solutia UK Ltd