

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent CG0061701

Nature of Discharge(s): SEWAGE EFF/TREATED EFF/CONTINUOUS
at LOWER CORRIS STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to: * delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed: **Dated:**

Name (block capitals): **Position:**





Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru

National Rivers Authority
Welsh Region

Consent No. CG00617-01

WATER ACT 1989

Under Section 113 and Schedule 12 of the Water Act 1989 and all other enabling powers the National Rivers Authority hereby gives this

V A R I A T I O N O F C O N S E N T

On : DWR CYMRU CYFYNGEDIG

Of : Plas y Ffynnon, Cambrian Way, Brecon, Powys LD3 7HP


In respect of the previous Consent No: CG00617-01 Issued on: 29th August 1981
and Varied on: 30th January 1985

For the discharge of: Treated Sewage Effluent

From : CORRIS ISAF SEWAGE TREATMENT WORKS

THE CONSENT IS HEREBY VARIED AS FOLLOWS:-

1. For the purpose of this consent variation,
"Winter" shall be understood to commence on 1st October until 31st March
and
"Summer" shall be understood to commence on 1st April until 30th September
2. This Variation should be retained with Consent No. CG00617-01 dated 29th August 1981 and which was further varied on 30th January 1985.

This Consent Variation is given on: 1st November 1991 on behalf of the
Authority by:  Divisional Scientist

Aelod Rhanbarthol o'r Bwrdd
Yr Athro Ron Edwards

Rheolwr Rhanbarth Cyffredinol
Dr John Stoner

Highfield, Ffordd Priestley
Caernarfon
Gwynedd, LL55 1HR
Ffôn: Caernarfon (0286) 672247
Ffacs: (0286) 4451

Cyfreithiwr Adronnol (Gogledd)/Divisional Solicitor (Northern)
David Bathers LL.B.

Regional Board Member
Professor Ron Edwards

Regional General Manager
Dr John Stoner

Highfield, Priestley Road
Caernarfon
Gwynedd, LL55 1HR
Tel: Caernarfon (0286) 672247
Fax: (0286) 4451

CONSENT VARIATION

RIVERS (CONTROL OF POLLUTION) ACTS 1951-1961

THE WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

I am directed by the Secretary of State for Wales to refer to the discharge consent in respect of the CORRIS... (SAF... sewage treatment works dated 29... AUGUST... 1981.

The Secretary of State for Wales, having consulted with the Welsh Water Authority, hereby gives notice that in exercise of his powers under Articles 4(8) and 8 of the Water Authorities (Control of Discharges) Order 1978 (SI 1978 No 1210), the conditions imposed on the said consent shall be varied in the following terms:

CONDITIONS

The quality and quantity of effluent shall not exceed the following maximum values:

	Milligrams per Litre	
	Summer (15 April-15 October)	Winter (16 October-14 April)
Biochemical Oxygen Demand (+ ATU) over 5 days at 20°C	50	50
Suspended Solids dried at 105°C;	75	75
Ammoniacal ammonia expressed as nitrogen	15	30
Dry Weather Flow	litres per second or ... 109 ... metres cubed per day.	

This variation takes effect from the ..29. January 1985.

This notice should be retained with the consent dated 29... AUGUST. 1981

George Roberts
WEP Division
Welsh Office