

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

| | |
|--------------------------------|---------------------------------------------------------------------------------------|
| Permit Number | EPR/BX7282IS |
| Name of operator | AB InBev UK Ltd |
| Location of Facility | Magor Brewery, The Brewery, Wilcrick, Magor, Caldicot, Monmouthshire, NP26 3RA |
| Time and date of the detection | 10:00 16/04/2024 |

| | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------|--|
| (a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment | |
| To be notified within 24 hours | |
| Date and time of the event | |
| Reference or description of the location of the event | |
| Description of where any release into the environment took place | |
| Substances(s) potentially released | |
| Best estimate of the quantity or rate of release of substances | |
| Measures taken, or intended to be taken, to stop any emission | |
| Description of the failure or accident. | |

| | |
|---------------------------------------------------------------------------|------------------------------------------------------------------------------------------|
| (b) Notification requirements for the breach of a permit condition | |
| To be notified within 24 hours | |
| Emission point reference/ source | Final Effluent Sample Point ST 4369 8494 |
| Parameter(s) | Total Nitrogen (TN) mg/l (daily average) |
| Limit | 20 |
| Measured value and uncertainty | 31.2 |
| Date and time of monitoring | 15/04/2024 |
| Measures taken, or intended to be taken, to stop the emission | FeCl3 Dosing installed. Aerobic trickle filter pipework upgrade project underway. |

| Time periods for notification following detection of a breach of a limit | |
|--------------------------------------------------------------------------|---------------------|
| Parameter | Notification period |
| | |
| | |
| | |

| (c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment: | |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-----|
| To be notified within 24 hours | |
| Description of where the effect on the environment was detected | N/A |
| Substances(s) detected | N/A |
| Concentrations of substances detected | N/A |
| Date of monitoring/sampling | N/A |

Part B - to be submitted as soon as practicable

| | |
|--------------------------------------------------------------------------------------------------------------------------------------------------------|---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| Any more accurate information on the matters for notification under Part A. | Total Phosphorous and Total Nitrogen are new parameters requiring measuring on EPR/BX7282IS since 4 th December 2023. |
| Measures taken, or intended to be taken, to prevent a recurrence of the incident | Total Phosphorous discharged can be controlled with FeCl ₃ dosing into the effluent. This system was commissioned through week 49 2023. Total Nitrogen requires plant upgrades that are underway and budgeted for 2024 Capital Expenditure. |
| Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission | None |
| The dates of any unauthorised emissions from the facility in the preceding 24 months. | None before 4/12/23 |

| | |
|------------------|--------------------------|
| Name* | Kyle Morgan |
| Post | ES Manager Magor Brewery |
| Signature | Kyle Morgan |
| Date | 16/04/2024 |

* authorised to sign on behalf of the operator