

## Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

### Part A

|                                |   |
|--------------------------------|---|
| Permit Number                  | <b>EPR/BX7282IS</b>   |
| Name of operator               | <b>AB InBev UK Ltd</b>  |
| Location of Facility           | <b>Magor Brewery, The Brewery, Wilcrick, Magor, Caldicot, Monmouthshire, NP26 3RA</b> |
| Time and date of the detection | <b>10:00 04/06/2024</b>   |

|  |  |
|--|--|
| <b>(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment</b> |  |
| <b>To be notified within 24 hours</b>  |  |
| Date and time of the event   |  |
| Reference or description of the location of the event  |  |
| Description of where any release into the environment took place   |  |
| Substances(s) potentially released   |  |
| Best estimate of the quantity or rate of release of substances   |  |
| Measures taken, or intended to be taken, to stop any emission  |  |
| Description of the failure or accident.  |  |

|   |  |
|---|--|
| <b>(b) Notification requirements for the breach of a permit condition</b> |  |
| <b>To be notified within 24 hours</b>                                     |  |
| Emission point reference/ source  | <b>Final Effluent Sample Point ST 4369 8494</b>  |
| Parameter(s)  | <b>Total Nitrogen (TN)<br/>mg/l (daily average)</b>                                      |
| Limit   | <b>20</b>  |
| Measured value and uncertainty  | <b>24</b>  |
| Date and time of monitoring   | <b>31/05/2024</b>  |
| Measures taken, or intended to be taken, to stop the emission             | <b>FeCl3 Dosing installed. Aerobic trickle filter pipework upgrade project underway.</b> |

| Time periods for notification following detection of a breach of a limit |                     |
|--|---------------------|
| Parameter  | Notification period |
|  |                     |
|  |                     |
|  |                     |

| (c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment: |     |
|--|-----|
| To be notified within 24 hours   |     |
| Description of where the effect on the environment was detected  | N/A |
| Substances(s) detected   | N/A |
| Concentrations of substances detected  | N/A |
| Date of monitoring/sampling  | N/A |

**Part B - to be submitted as soon as practicable**

|  |   |
|--|---|
| Any more accurate information on the matters for notification under Part A.  | Total Phosphorous and Total Nitrogen are new parameters requiring measuring on EPR/BX7282IS since 4 <sup>th</sup> December 2023.  |
| Measures taken, or intended to be taken, to prevent a recurrence of the incident   | Total Phosphorous discharged can be controlled with FeCl <sub>3</sub> dosing into the effluent. This system was commissioned through week 49 2023.<br><br>Total Nitrogen requires plant upgrades that are underway and budgeted for 2024 Capital Expenditure. |
| Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission | None  |
| The dates of any unauthorised emissions from the facility in the preceding 24 months.  | None before 4/12/23   |

|                  |                          |
|------------------|--------------------------|
| <b>Name*</b>     | Kyle Morgan              |
| <b>Post</b>      | ES Manager Magor Brewery |
| <b>Signature</b> | Kyle Morgan              |
| <b>Date</b>      | 04/06/2024               |

\* authorised to sign on behalf of the operator