



Sheet Size A1+1 594 x 1051

HAZARD SCHEDULE			
SAFETY, HEALTH AND ENVIRONMENTAL INFORMATION			
THE FOLLOWING NOTES HIGHLIGHT SIGNIFICANT RESIDUAL HAZARDS IDENTIFIED BY THE DESIGNER. TYPICAL HAZARDS THAT SHOULD BE IDENTIFIED BY A COMPETENT CONTRACTOR ARE NOT INCLUDED. THE CONTRACTOR SHALL UNDERTAKE THE CONSTRUCTION TASKS USING AN APPROVED SAFE SYSTEM OF WORK (SSOW)			
SHOULD ANY ADDITIONAL HAZARDS BE IDENTIFIED DURING THE COURSE OF THE WORKS, THE CONTRACTOR SHALL NOTIFY ALL RELEVANT MEMBERS OF THE DESIGN TEAM			
COMPLY PRO REF	ARCADIS HAZARD REF	HAZARD TITLE	HAZARD DESCRIPTION
TRAN01-CVL-HZD-4640	ARC167	PRESENCE OF EXISTING SERVICES AND UNDERGROUND SERVICES	RISK TO GROUND WORKERS DUE TO BURIED SERVICES DURING EXCAVATIONS FOR FOUNDATIONS
TRAN01-CVL-HZD-4641	ARC168	PRESENCE OF CONTAMINATED LAND	CONTAMINATED SOIL CONTAINING COAL BASED RESIDUE/ASBESTOS CAUSING SHORT AND LONG TERM HEALTH EFFECTS TO GROUND WORKERS
TRAN01-CVL-HZD-4645	ARC172	INSTABILITY OF TEMPORARY WORKS DUE TO POOR GROUND CONDITIONS	RISK OF DEEP EXCAVATIONS COLLAPSING ON SITE WORKERS.
TRAN01-CVL-HZD-4704	ARC226	CONSTRUCTION CO-ORDINATION WITH OTHERS	RISK OF POOR CO-ORDINATION BETWEEN SUBSTRUCTURE AND SUPERSTRUCTURE INSTALLATIONS
TRAN01-CVL-HZD-4708	ARC230	WORKING FROM HEIGHT	RISK OF SITE WORKERS/PLANT/MACHINERY FALLING INTO EXCAVATIONS
TRAN01-CVL-HZD-4709	ARC231	DESTABILISING OF ADJACENT STRUCTURES DURING CONSTRUCTION	RISK OF IMPACT CAUSING DESTABILISING/COLLAPSE OF EXISTING STRUCTURES AND TRAIN WASH RELATED STRUCTURES.SUITABLE PROVISIONS AND CONSTRUCTION SEQUENCING TO BE IMPLEMENTED BY THE CONTRACTOR