

Schedule 5 Notification


PART B

Permit Number:	BR9715IB
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Site Effluent Discharge W2
Time and date of the emission:	09/07/2024 at ~02:30 – 04:15

Any more accurate information on the matters for notification under Part A	<p>The details of the event are as Notified in the Part A i.e. ~490m³ of Surface Water discharged during the specified (cease discharge) time. As mentioned, this was due to unexpected heavy rainfall which occurred at the time. In addition, the situation was also hampered by some other factors, namely;</p> <ul style="list-style-type: none"> i) Shutdown preparations for the forthcoming outage meant that a storage lagoon. which would otherwise have been available had been reconfigured for alternative discharge arrangements ii) Effluent discharge pumping rates have been reduced in order to better manage pressure fluctuations to limit unnecessary stress on the pipeline – thus resulting in a decreased capacity to deal with the level of rainfall experienced <p>None of the permitted effluent parameters were out of specification for the period</p>
Measures taken, or intended to be taken, to prevent a recurrence of the incident	Pumping configuration is continuing to be optimized pending Phase III of the effluent pipeline upgrade. The additional (East Lagoon) storage will once again be available upon resumption of operations after the shutdown
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment or harm which has been or may be caused by the emission	None proposed

The dates of any unauthorised emissions from the installation in the preceding 24 months	31/07/2024 - Effluent Cease Discharge [This Notification] 18/06/2024 - T66 Storage Pump 24/01/2024 - Boiler 16 CO 08/01/2024 - Dequest Amino Recirc Line 14/12/2023 - Formalin in Effluent 12/12/2023 - Boiler 16 CO 04/12/2023 - Effluent Cease Discharge 17/11/2023 - Effluent Pipeline Offsite 13/10/2023 - Benzene Release to Separator 15/09/2023 - Boiler 16 CO 29/08/2023 - Effluent Circulation Pipeline Leak 06/09/2023 - Formalin in Effluent 06/02/2023 - Dequest Amino 24/11/2022 - Effluent Cease Discharge
---	---

*** Signed:**



Date: 01/08/2024

* authorised to sign on behalf of Solutia UK Ltd