

Schedule 5 - Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/AB3093CA
Name of operator	WELSH WATER ORGANIC ENERGY (CARDIFF) LTD
Location of Facility	Tremorfa Anaerobic Digestion Facility, Tide Fields Road, Tremorfa, Cardiff CF24 5SP
Time and date of the detection	

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment	
To be notified Immediately	
Date and time of the event	21st march 2019 / 12:53 pm
Reference or description of the location of the event	WWOE cardiff – CHP & Flare slab.
Description of where any release into the environment took place	Flare stack
Substances(s) potentially released	TVOC & CO
Best estimate of the quantity or rate of release of substances	62.02 mgC/m3 & 141.98 mg/m3
Measures taken, or intended to be taken, to stop any emission	N/A
Description of the failure or accident.	N/A

(b) Notification requirements for the breach of a permit condition	
To be notified immediately	
Emission point reference/ source	Flare stack
Parameter(s)	TVOC 10mgC & CO 50 mg/m3
Limit	10 mgC & 50 mg/m3
Measured value and uncertainty	62.02 & 141.98
Date and time of monitoring	21/03/2019
Measures taken, or intended to be taken, to stop the emission	Looking for onsite solutions to improve and stay within parameters

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified immediately	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Ross Wellington
Post	Team Leader
Signature	R.wellington
Date	08/10/2019

* authorised to sign on behalf of the operator