

Permit Reference Number: BL3986ID

Operator: Aberthaw Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Air 11 / 19/07/2016

**Six-monthly Reporting of Particulate Emissions to Air from Emission Points A4, A5, A6 & A11
for the period from 01/06/23 to 30/12/23**

Emission Point	Parameter	Emission Limit Value (mg/Nm ³)	Result (mg/Nm ³) 1 st Six months	Result (mg/Nm ³) 2 nd Six months	Test Method	Sample Date & Times	Uncertainty
A4	Particulate Matter	10	12.73		BS EN 13284-1	28.3.2023 10:24 – 12:31	0.54
A5	Particulate Matter	10	-	10.17	BS EN 13284-1	21.9.2023 13:30 – 15:24	0.60
A6	Particulate Matter	10	-		BS EN 13284-1	-	-
A11	Particulate Matter	10	-		BS EN 13284-1	-	-

Signed: ██████████ Date 12/01/2024
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)