

Schedule 1 – 5.1.1 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	W1 Effluent
Time and date of the emission:	Commencing the week leading up to: w/e 08/10/2019

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
PCP	Discharge to Estuary	327 g/wk [highest reading] Vs 250 g/wk mass limit	N/A

Measures taken, or intended to be taken, to stop the emission:	Due to elevated rainfall, PCP contaminated groundwater has been finding it's way into the site drainage system, effectively bypassing the Reed Beds treatment units Some options under evaluation & discussion to reconfigure the system to; reduce groundwater levels and thereby prevent movement of PCP by this mechanism Additional information to follow in Part B
---	--

* Signed: 

Date: 18/10/2019

* authorised to sign on behalf of Solutia UK Ltd