

Date of form 13/10/14

NOT YET COMMISSIONED

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: December 2023

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator:



Date: 12/01/2024

Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [December 2023](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	01	01	24/10/2023
Suspended Solids mg/l	50	2	3	24/10/2023
Mineral oil and hydrocarbons mg/l	5	0.6	1.31	02/11/2023
Suspended Solids mg/l	50	12	12	02/11/2023
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	06/12/2023
Suspended Solids mg/l	50	16	18	06/12/2023

Signed on behalf of the Operator:

Date: 12/01/2024



Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [December 2023](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.40	7.07	7.54	7.60
Total suspended solids mg/l	600	0.50	0.52	0.60	0.60
Total chemical oxygen demand (COD) mg/l	3600	3.00	32.08	67.60	76.00
Free or emulsified grease or oil mg/l	100	3.98	10.62	17.16	19.80
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	86.00	177.62	294.80	350.00
Ammoniacal nitrogen as N mg/l	30	1.61	4.42	9.02	11.80
Daily flow m ³ /day	800	1.87	24.20	33.24	33.3
Maximum flow m ³ /h	34	44.94	580.81	797.81	799.94

Signed on behalf of the Operator:

Date: 12/01/2024

