

Compliance Assessment Report

Report ID:
CAR_NRW0034124

This form will report compliance with your permit as determined by an NRW officer

Site	Tondu Waste Transfer Station	Permit Ref	GP3690LR		
Operator/Permit holder	Kier Services Limited				
Regime	Waste Operations				
Date of assessment	30/10/2018	Time in	N/A	Out	N/A
Assessment type	Report/Data Review				
Parts of the permit assessed	Fire Prevention and Mitigation Plan				
Lead officer's name	Davies, Gareth				
Accompanied by					
Recipient's name/position	Gareth Barnes/ Management	Date issued	30/10/2018		

Section 1 – Compliance Assessment Summary

This is based on the requirements of the permit under the Environmental Permitting Regulations or the licence under the Water Resources Act 1991 as amended by the Water Act 2003. A detailed explanation is captured in "Compliance Assessment Report Detail" (Section 2) and any actions you may need to take are given in the "Action(s)" (section 4). This summary details where we believe any non-compliance with the permit has occurred, the relevant condition and how the non-compliance has been categorised using our Compliance Classification Scheme (CCS). CCS Scores can be consolidated or suspended where appropriate, to reflect the impact of some non-compliances more accurately. For more details of our CCS scheme, contact your local office.

Permit conditions and compliance summary	CCS Category	Condition(s) breached
D2 - Incident Management - Accidents, emergency and incident planning	C3	3.4.1

KEY: See Section 5 for breach categories, suspended scores will be indicated as such.

A = Assessed or assessed in part (no evidence of non-compliance), **X** = Action only,

O = Ongoing non-compliance, not scored.

Number of breaches recorded	1	Total compliance score (see section 5 for scoring scheme)	4
-----------------------------	---	--	---

If the Number of breaches recorded is greater than zero, please see Section 3 for our proposed enforcement response

Section 2 – Compliance Assessment Report Detail

This section contains a report of our findings and will usually include information on:

- The part(s) of the permit that were assessed (eg. Maintenance, training, combustion plant, etc)
- Where the type of assessment was 'Data Review' details of the report/results triggering the assessment
- Any non-compliances identified
- Any non-compliances with directly applicable legislation
- Details of any multiple non-compliances
- Information on the compliance score accrued inc.
- Details of advice given
- Any other areas of concern
- Any actions requested
- Any examples of good practice
- A reference to photos taken

On 1 August 2017, Natural Resources Wales published an updated version to standard rules set SR2008 No3. Kier Services Limited hold an environmental permit to operate under this standard rules set.

The updated version of the standard rules set included Section 3.4 - Fire. Condition 3.4.1 states that: The operator shall manage and operate the activities in accordance with a written fire prevention plan using the current, relevant fire prevention plan guidance.

On 20 October 2017, you provided Natural Resources Wales with your Fire Prevention and Mitigation Plan (FPMP). Following review of your FPMP in accordance with Fire Prevention and Mitigation Plan Guidance – Waste Management Version 2 August 2017 (guidance), I have the following comments and associated updates that are required to the FPMP. These comments have been written in conjunction with your regulatory officer.

The FPMP guidance sets out what must be in your FPMP, and what should be in you FPMP. The comments have been divided in to these sections. For the "must" requirements you are required to include these in your FPMP. For the "should" requirements, please consider these, give alternatives or explain why they may not apply to your operations.

Section 5 - Fire Prevention and Mitigation Plan Contents

Following review of your FPMP it does not contain the following requirements as set as musts out in the above section of the guidance.

- the amount and type of waste received daily and how it is managed
- the maximum size of any waste pile (in m3), stipulating the maximum length, width and depth
- how safe access to the site for fire and rescue services and other emergency responders is achieved

You must include these requirements in your FPMP

Action: The above requirements of the guidance must be included in a revised FPMP.

The guidance requires that you should also include the following actions to be taken should a fire occur.

- separating unburned material from the fire using heavy plant
- separating burning material from the fire to quench it with hoses or in pools or tanks of water (this will reduce the amount of firewater produced)

Action: You shall include these requirements/actions in your FPMP. Where any of these requirement/actions have not been included a justification shall be provided.

Section 5 - Site Plan

Following review of your site plan it does not contain the follow requirements as set out as musts in the above section of the guidance.

- any areas where hazardous materials are stored on site (location of gas cylinders, process areas, chemicals, piles of combustible materials, oil and fuel tanks)
- main access routes for fire engines and any alternative access
- access points around the site perimeter to assist firefighting – see table in guidance for typical FRS vehicle access requirements

- any watercourse, borehole or well located within or near the site
- Location of the quarantine area

You must include these requirements in your site plan.

Action: The above requirements of the guidance must be included in a revised FPMP.

Section 8 – Managing waste material stacks and separation distances

From the information provided within Section 6, it was not possible to fully assess your plan in accordance with the above section of the guidance.

Action – You must demonstrate how you intend to comply with this section of the guidance. You must provide detail on where each waste type is stored on any associated plans so that an assessment can be made.

Section 11 – Enclosing Stacks Using Bays and Walls

Following review of your FPMP it does not contain the following requirements as set out as should in the above section of the guidance

- No evidence has been provided as to whether the bays/walls provide a 120 minute fire resistance period.
- the construction of the walls in terms of how they offer a thermal barrier and enable cooling
- how you will ensure segregation of materials
- how calculation of flame height and radiation has been taken into account in preventing the spread of fire between piles
- prevention of brands or lighted material moving outside the bay walls
- prevention of bridging across or around walls
- how a 'freeboard' space of 1m at the top and sides of the walls will be physically retained at all times.

Action - You shall include the above information on enclosing stacks using bays and walls. Where any of these measures have not been included a justification shall be provided as to why it has not been considered or included.

Section 13 – Waste Stored in Containers

Following review of your plan it does not contain the following requirements as set out as musts in the above section of the guidance.

- each container must be accessible so any fire inside it can be extinguished. The location of the containers storing waste has not been provided.

You must include these requirements in your plan.

Action: The above requirements of the guidance must be included in a revised FPMP.

Following review of your FPMP it does not contain the following requirements as set out as should in the above section of the guidance

- You should be able to move containers as soon as is reasonably practicable in a safe manner to prevent the fire spreading. You should set out in your FPMP the procedures you will put in place to allow this to happen.

Action - You shall include the above information on waste stored in containers. Where any of these measures have not been included a justification shall be provided as to why it has not been considered or included.

17 – Fire Detection

Comments to be provided by South Wales Fire & Rescue Service

18 – Fire Suppression Systems

Comments to be provided by South Wales Fire & Rescue Service

19 – Firefighting Strategy

Comments to be provided by South Wales Fire & Rescue Service

20 – Water Supplies

No information on supply rate of hydrant has been provided

Comments to be provided by South Wales Fire & Rescue Service

21 – Managing Water Run-off

Comments to be provided by South Wales Fire & Rescue Service

22 – Designated Quarantine Area

Following review of your FPMP it does not contain the following requirements as set out as should in the above section of the guidance.

- The location of the quarantine area
- The quarantine area should hold at least 50% of the volume of the largest stack.

Action - You shall include information on a designated quarantine area. Where any of these measures have not been included a justification shall be provided as to why it has not been considered or included.

23 – During and After an Incident

Following review of your FPMP it does not contain the following requirements as set out as must in the above section of the guidance.

- Diverting incoming wastes to alternative sites during a fire
- contractors that might be used to assist with additional plant for firefighting techniques, removal of waste material, containment and removal of excess water run-off

You must include these requirements in your FPMP

Action: The above requirements of the guidance must be included in a revised FPMP.

Non-Compliance Score

Condition 3.4.1 states “The operator shall manage and operate the activities in accordance with a written fire prevention plan using the current, relevant fire prevention plan guidance.” The current FPMP submitted by Kier Services Ltd does not meet the requirement set out in the current, relevant fire prevention plan guidance. This non-compliance has been scored a CCS3 under D2 Incident Management – Accident, emergency and incident planning.

Please provide a date for agreement with NRW, for when you will provide an updated FPMP taking account of the points highlighted above by 13 November 2018.

Failure to provide a date for agreement and submission of a revised FPMP, may result in a Regulation 36 Notice being served.

Consultation with South Wales Fire and Rescue Service (SWFRS)

NRW will be consulting with SWFRS once the above actions have been completed. Any comments from SWFRS will be provided under separate cover, but shall be considered linked to this Compliance Assessment Report. You may be required to update your FPMP following comments from SWFRS.

In this document 'Natural Resources Wales' means the Natural Resources Body for Wales established by Article 3 of the Natural Resources Body for Wales (Establishment) Order 2012.

You should note that the Natural Resources Body for Wales has been formed by bringing together the Countryside Council for Wales, Forestry Commission Wales and Environment Agency Wales. The Natural Resources Body for Wales has been empowered to exercise Welsh devolved functions since 1st April 2013 and has, generally, taken over the responsibilities of the Countryside Council for Wales, the Forestry Commissioners and the Environment Agency in Wales.

END

EPR Compliance Assessment Report

**Report ID:
CAR_NRW0034124**

This form will report compliance with your permit as determined by an NRW officer

Site	Tondu Waste Transfer Station	Permit Ref	GP3690LR
Operator/Permit holder	Kier Services Limited	Date	30/10/2018

Section 3 – Enforcement Response

You must take immediate action to rectify any non-compliance and prevent repetition. Non-compliance with your permit conditions constitutes an offence and can result in criminal prosecutions and/or suspension or revocation of a permit. Please read the detailed assessment in Section 2 and the steps you need to take in Section 4 below.

In respect of the above non-compliance you have been issued with a warning. At present we do not intend to take further enforcement action. This does not preclude us from taking additional enforcement action if further relevant information comes to light or offences continue.

Section 4 – Action(s)

This section summarises the actions identified during the assessment along with the timescales for when they will need to be completed.

Criteria Ref.	CCS Category	Action required/advised	Due Date
See Section 1 above			
D2	C3	A date shall be provided for agreement with NRW, for when a revised FPMP shall be submitted.	13/11/2018

Section 5 – Compliance notes for the Operator

To ensure you correct actual or potential non-compliance we may

- Advise on corrective actions verbally or in writing
- Require you to take specific actions verbally or in writing
- Issue a notice
- Require you to review your procedures or management system
- Change some of the conditions of your permit
- Decide to undertake a full review of your permit

Any breach of a permit condition is an offence and we may take legal action against you

- We will normally provide advice and guidance to assist you to come back into compliance either after an offence is committed or where we consider that an offence is likely to be committed. This is without prejudice to any other enforcement response that we consider may be required.
- Enforcement action can include the issue of a formal caution, prosecution, the service of a notice and/or suspension or revocation of the permit.

See our Enforcement and Civil Sanctions guidance for further information

This report does not relieve the site operator of the responsibility to

- Ensure you comply with the conditions of the permit at all times and prevent pollution of the environment
- Ensure you comply with other legislative provisions which may apply

Non-compliance scores and categories

CCS category	Description	Score
C1	A non-compliance that could have a major environmental effect	60
C2	A non-compliance which could have a significant environmental effect	31
C3	A non-compliance which could have a minor environmental effect	4
C4	A non-compliance which has no potential environmental effect	0.1

Operational Risk Appraisal (Opra) - Compliance assessment findings may affect your Opra score and/or your charges. This score influences the resource we use to assess permit compliance.

Section 6 – General information

Data protection notice

The information on this form will be processed by the Natural Resources Wales (NRW) to fulfil its regulatory and monitoring functions and to maintain the relevant public register(s). The NRW may also use and/or disclose it in connection with:

- Offering/providing you with its literature/services relating to environmental matters
- Consulting with the public, public bodies and other organisations (eg. Health and Safety Executive, local authorities) on environmental issues
- Carrying out statistical analysis, research and development on environmental issues
- Providing public register information to enquirers
- Investigating possible breaches of environmental law
- Assessing customer service satisfaction and improving its service
- Freedom of Information Act/Environmental Regulations request

The NRW may pass it on to its agents/representatives to do these things on its behalf. You should ensure that any persons named on this form are informed of the contents of this data protection notice.

Disclosure of information

The NRW will provide a copy of this report to the public register(s). However, if you consider that any information contained in this report should not be released to the public register(s) on the grounds of commercial confidentiality, you must write to your local area office within fifteen working days of receipt of this form indicating which information it concerns and why it should not be released, giving your reasons in full.

Customer charter

What can I do if I disagree with this compliance assessment report?

If you are unable to resolve the issue with your site officer, you should firstly discuss the matter with officer's line managers using the informal appeals procedure. If you wish to raise your dispute further through our official Complaints and Commendations procedure, phone our general enquiry number 0300 065 3000 (Mon to Fri 08.00 – 18.00) and ask for the Customer Contact team or send an email to enquiries@naturalresourceswales.gov.uk. If you are still dissatisfied you can make a complaint to the Public Services Ombudsman for Wales. For advice on how to complain to the Ombudsman phone their helpline on 0845 607 0987.

Welsh Language

If you would like this form in Welsh please contact your Regulatory Officer.