

**Consent to Discharge
Certificate of Holder**



Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BG0042201

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at LLANGWM STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* **Holder of the above consent** which will be/was* transferred to:

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed: Dated:

Name (block capitals): Position:

(to be completed when signing
on behalf of corporate bodies)



LOCAL GOVERNMENT ACT 1972 WATER ACT 1973
RIVERS (PREVENTION OF POLLUTION) ACTS 1951-1961
WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

NOTIFICATION OF VARIATION OF CONSENT
for a discharge of treated sewage effluent

To : WELSH WATER AUTHORITY

This Notice is issued under the above-mentioned Acts and Order and all other enabling powers as a NOTICE DEEMED TO HAVE BEEN GIVEN BY THE SECRETARY OF STATE FOR WALES, in respect of the existing discharge of treated sewage effluent from the Authority's :

LLANGWM SEWAGE TREATMENT WORKS

via an existing outlet and subject hitherto to a previous consent as specified below
THE EXISTING OUTLET is to : Beggars Reach/Daugleddau

at National Grid Reference : SM 9955 0873

and has been shown marked : Discharge Point

on the attached Plan, No. : RW/0189/T/1

THE PREVIOUS CONSENT was : the Consent Reference No. 852

granted on : 21st July 1964

by : South West Wales River Board

to : Haverfordwest Rural District Council

The Authority submitted this Notification of Variation on : 12th May 1982 to the Secretary of State for Wales in the form of a draft and the Secretary of State has NOT, within the relevant period, given notice of his intention to determine this matter. This discharge is therefore (in substitution for all the conditions hitherto in force) subject only to the following conditions as from : 12th August 1982

CONDITIONS

1. The discharge shall consist only of treated sewage effluent from the above works.
2. The quality and quantity of effluent shall not exceed the following maximum values

<u>Determinand</u>	<u>Value</u>	<u>Unit</u>
Biochemical Oxygen Demand (+ATU) over 5 days at 20°C	40	milligrams per litre
Suspended Solids dried at 105°C	60	milligrams per litre

Rate of discharge	12.4	litres per second
-------------------	------	-------------------

Volume during any period of 24 consecutive hours	1072	cubic metres
--	------	--------------

Volume discharged under 'dry weather conditions' during any period of 24 consecutive hours	178.6	cubic metres
--	-------	--------------

3. Adequate facilities shall be provided for the taking of samples of the effluent at outlet from humus tank

The terms of this Notice will not, without the consent in writing of the person to whom this Notice is given, (or his successor), be altered before the expiration of the period ending with the Twelfth day of August 1984.

This Notification is issued by the Directorate of Scientific Services, Headquarters,

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

Reference - 25-42.

No. 8600/42201

CAT. No. R.B.12 SHAW & SONS LTD., FETTER LANE, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES
25th June 1964.	Haverfordwest Rural District Council. Additional discharge from Haverford now known as Buxton North Sewerage Scheme.
USE OF NEW OR ALTERED OUTLET CONDITIONS IMPOSED WITH RESPECT TO:- (I) PRECISE LOCATION OF OUTLET Outlet to be located on right bank of Bagges Reach in the Dan Breddan above low water mark ordinary tides. Map of O.S.S. Rembs 25" S.M. 140 Grid reference 996.085. (II) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE) Outlet into the stream to be by means of a 12" pipe. Facilities must be made available for sampling to be carried out at the Sewerage works. (III) USE OF OUTLET Restricted to sewage effluent produced at Snod's Hill, Mountain, Port Pior, Houghton and Haverford Valley. (IV) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES <u>Pump Relief Outlets</u> The two pump relief outlets provided at Snod's & Houghton should come into operation in emergencies only. It is recommended that the pump house sumps should be increased in size to further reduce the necessity of the pump relief for overflowing.	DISCHARGE OF TRADE OR SEWAGE EFFLUENT CONDITIONS IMPOSED WITH RESPECT TO:- (I) NATURE AND COMPOSITION OF DISCHARGE Discharge to be restricted to fully treated domestic sewage and to conform to the following standards. pH value not less than 6 or more than 8.5 5 day B.O.D. at 20°C not to exceed 30 p.p.m. Total suspended solids not to exceed 30 p.p.m. Effluent shall pass the methylene blue stability test (5 days at 20°C). Effluent shall be well nitrified and contain not less than 10 p.p.m. of nitrate (expressed as N). Effluent not to contain any other polluting substance or substances. (II) TEMPERATURE OF DISCHARGE not to exceed 21°C. (III) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES not to be more than 29,300 g.p.d. at d.w.f. (It is understood that final treatment will be given to b + d.w.f.). * (IV) PROVISION OF FACILITIES FOR TAKING SAMPLES * (V) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S.5(2) OF 1961 ACT 30th June 1966.
REMARKS-	REMARKS-

