

**Water Resources Act 1991**  
as amended by the Environment Act 1995  
**Consent to Discharge**  
**Certificate of Holder**



**ENVIRONMENT-  
AGENCY**

**Part A**

To: DWR CYMRU CYFYNGEDIG  
CONSENTS REGULATION OFFICER  
PLAS-Y-FFYNNON  
CAMBRIAN WAY  
BRECON LD3 7HP

The Environment Agency ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BG0034601

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS  
at CASTLEMARTIN STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

**Part B**

Please complete in block capitals or type.

To:

**Water Resources Act 1991: Notice of transfer of consent to discharge**

Consent:

Name:

Address:

I/We\* hereby serve notice on the Agency that I/we\* am/are\* no longer a/the\* Holder of the above consent which will be/was\* transferred to:

\* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s): .....

Signed: .....

Dated: .....

Name (block capitals): .....

Position: .....

JWE/5/96

(to be completed when signing  
on behalf of corporate bodies)



Welsh Off Ref

Form SS.RW2

WWA HQ Ref

RW/0336/1/1

Sheet 1  
of 1

LOCAL GOVERNMENT ACT 1972      WATER ACT 1973  
RIVERS (PREVENTION OF POLLUTION) ACTS 1951-1961  
WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

NOTIFICATION OF VARIATION OF CONSENT  
for a discharge of treated sewage effluent

To :

WELSH WATER AUTHORITY

This Notice is issued under the above-mentioned Acts and Order and all other enabling powers as a NOTICE DEEMED TO HAVE BEEN GIVEN BY THE SECRETARY OF STATE FOR WALES, in respect of the existing discharge of treated sewage effluent from the Authority's :  
CASTLEMARTIN SEWAGE TREATMENT WORKS

via an existing outlet and subject hitherto to a previous consent as specified below.

THE EXISTING OUTLET is to : the Stembridge Stream

at National Grid Reference : SR 9086 9936

and has been shown marked : Discharge Point

on the attached Plan, No. : RW/0336/1/1

THE PREVIOUS CONSENT was : The variation of Consent      Reference No. -

granted on : 10th June 1964

by : South West Wales River Board

to : Pembroke Rural District Council

The Authority submitted this Notification of Variation on : 12th November 1981 to the Secretary of State for Wales in the form of a draft and the Secretary of State has NOT, within the relevant period, given notice of his intention to determine this matter. This discharge is therefore (in substitution for all the conditions hitherto in force) subject only to the following conditions as from : 12th February 1982.

CONDITIONS

1. The discharge shall consist only of treated sewage effluent from the above works.
2. The quality and quantity of effluent shall not exceed the following maximum values:

<u>Determinand</u>	<u>Value</u>	<u>Unit</u>
Biochemical Oxygen Demand (+ATU) over 5 days at 20°C	32	milligrams per litre
Suspended Solids dried at 105°C	42	milligrams per litre

Rate of discharge	1.1	litres per second
-------------------	-----	-------------------

Volume during any period of 24 consecutive hours	91.2	cubic metres
--	------	--------------

Volume discharged under 'dry weather conditions' during any period of 24 consecutive hours	30.4	cubic metres
--	------	--------------

3. Adequate facilities shall be provided for the taking of samples of the effluent at: outlet from humus tank.

The terms of this Notice will not, without the consent in writing of the person to whom this Notice is given, (or his successor), be altered before the expiration of the period ending with the Twelfth day of February 1984.

This Notification is issued by the Directorate of Scientific Services, Headquarters, Welsh Water Authority, Cambrian Way, Brecon, Powys.

# REGISTER OF CONDITIONS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951.

File Reference ES-2197.

BG 00 34601

CAT. NO. R.B.12 SHAW & SONS LTD., FETTER LANE, E.C.4. V7/1

NAME AND ADDRESS OF APPLICANT <i>Pembroke Rural District Council, Indoor House, Pembroke.</i>		DATE OF APPLICATION <i>14 August 1963.</i>
DATE ON WHICH CONDITIONS CAME INTO FORCE	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE CONDITIONS RELATE	
<i>11th October 1963.</i>	<i>Castlemeads Sewerage Scheme.</i>	
USE OF NEW OR ALTERED OUTLET		NEW DISCHARGE
CONDITIONS IMPOSED WITH RESPECT TO:-  (I) PRECISE LOCATION OF OUTLET <i>Left bank of Stambrook Stream, field No. 43. SR 909 993</i> <i>Map reference OS.2. Pemb. N11.2 and T11.14.</i>  (II) CONSTRUCTION OF OUTLET <small>(OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE)</small> <i>To be so constructed as to be accessible for sampling at all times.</i>  (III) USE OF OUTLET <i>Restricted to sewage effluent produced at Castlemeads</i>  (IV) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES		CONDITIONS IMPOSED WITH RESPECT TO:-  (I) NATURE AND COMPOSITION OF DISCHARGE <i>fully treated sewage conforming to the standards recommended by the Royal Commission on Sewage Disposal.</i>  (II) TEMPERATURE OF DISCHARGE <i>Atmospheric.</i>  (III) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES <i>not to exceed 5,100 gallons per day.</i> <i>Amended 14.3.64.</i> <i>not to exceed 6,700 gallons per day.</i>
		REMARKS:-  (1) Period of consent as specified under Section 5(2) of the Rivers (Prevention of Pollution) Act, 1961. (that is period before review). <i>Two years.</i>  (2) Date of operation of conditions and length. <i>31st day October 1965.</i>

