



Spill Frequency Trigger Exceedance Notification

Date of Exceedance: 01/09/2024

Water Company Name: Dŵr Cymru Welsh Water

Type of SFT Notification: Bathing Water

Asset Name: Combined Sewer Overflow at Dunns Lane/Park Street

Permit reference: BP0237402

Permit Spill Frequency : 5

Number of spills at issue of TEN : 7

Duration of spills (hrs): 6.5

Impacted Bathing/Shellfish Water Limeslade

NRW Environment Team: Swansea

**For any queries or further
information contact:** Gareth Griffiths

TEN History:

Year	2022	2023	2024	2025	2026	2027	2028	2029
TEN ?	No	Yes	Yes	-	-	-	-	-