

Date of form 13/10/14

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: June 2023

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator:

Date: 21/07/2023



Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: **June 2023**

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	2.88	0.6	06/04/2023
Suspended Solids mg/l	50	16	4	06/04/2023
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	04/05/2023
Suspended Solids mg/l	50	8	4	04/05/2023
Mineral oil and hydrocarbons mg/l	5	1.69	0.96	01/06/2023
Suspended Solids mg/l	50	24	7	01/06/2023

Signed on behalf of the Operator:

Date: 21/07/2023



Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [June 2023](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.2	6.7	7.4	7.7
Total suspended solids mg/l	600	8	22.8	49.5	72
Total chemical oxygen demand (COD) mg/l	3600	116	234.1	300.8	305
Free or emulsified grease or oil mg/l	100	2.3	8.59	16.46	20.3
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.5	0.6	1.18	1.3
Ammoniacal nitrogen as N mg/l	30	3.46	9.2	13.72	13.9
Daily flow m ³ /day	800	8.8	521.8	784.4	799.0
Maximum flow m ³ /h	34	0.4	21.7	32.7	33.3

Signed on behalf of the Operator:

Date: 21/07/2023

