

Date of form 13/10/14

Date of form 13/10/14

Date of form 13/10/14

Schedule 3 - Form Number: A3

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Air

Release Point: A2

Release for Quarter ending: [March 2023](#)

NIL RETURNED

Reporting Form A3			
Details of operation of by-pass stack			
Date	Time	Duration	Reason for Operation

Signed on behalf of the Operator:

Date: 17/04/2023



Schedule 3 - Form Number: W1

Operator: Kepak

Permit Number: AP3433ES

Installation: Dowlais Slaughterhouse

Release to Water

Release Point: W1, W2

Release for Quarter ending: [March 2023](#)

Reporting Form W1				
Parameter	Limit Value	Release Point W1	Release Point W2	Month and Date
Mineral oil and hydrocarbons mg/l	5	0.6	0.6	05/01/2023
Suspended Solids mg/l	50	7	6	05/01/2023
Mineral oil and hydrocarbons mg/l	5	0.86	0.6	03/02/2023
Suspended Solids mg/l	50	4	10	03/02/2023
Mineral oil and hydrocarbons mg/l	5	0.2	0.89	02/03/2023
Suspended Solids mg/l	50	15	6	02/03/2023

Signed on behalf of the Operator:

Date: 17/04/2023



Schedule 3 - Form Number: S1**Operator: Kepak****Permit Number: AP3433ES**

Installation: Dowlais Slaughterhouse

Release to Sewer

Release Point: S1

Release for Quarter ending: [March 2023](#)

Reporting Form S1					
Parameter	Limit Value(s)	Min	Average	95 th Percentile Value	Maximum
pH	6-11	6.4	6.7	6.94	7
Total suspended solids mg/l	600	13	35.0	67.6	82
Total chemical oxygen demand (COD) mg/l	3600	124	352.8	619.6	679
Free or emulsified grease or oil mg/l	100	2.12	11.0	36.03	43.4
Anionic synthetic detergent as manoxol OT mg/l	100	0.025	0.025	0.025	0.025
Dissolved oxygen mg/l	-	0.5	0.6	0.88	1
Ammoniacal nitrogen as N mg/l	30	4.6	17.2	24.65	25.2
Daily flow m ³ /day	800	125.8	579.0	796.9	799.1
Maximum flow m ³ /h	34	5.2	24.1	33.2	33.3

Signed on behalf of the Operator:

Date: 17/04/2023

