



Spill Frequency Trigger Exceedance Notification

Date of Exceedance: 30/09/2024

Water Company Name: Dŵr Cymru Welsh Water

Type of SFT Notification: Bathing Water

Asset Name: Settled Storm Overflow at Penybont Wastewater Treatment Works

Permit reference: BW3206201

Permit Spill Frequency : 5

Number of spills at issue of TEN : 6

Duration of spills (hrs): 78.25

Impacted Bathing/Shellfish Water Southerndown

NRW Environment Team: Bridgend, Rhondda Cynon Taff and Merthyr Tydfil

For any queries or further information contact: Gareth Griffiths

TEN History:

Year	2022	2023	2024	2025	2026	2027	2028	2029
TEN ?	No	Yes	Yes	-	-	-	-	-