



Applies to:
Navigator Terminals Windmill

Issue Number
9

Appendix 1

Site Name: Navigator Terminals Windmill Ltd

Permit Number: KP3734SH

Parameter	Analytical method	Value recorded	Permit limits	Within permit limits? (Y/N)
pH	Standard glass probe [Dow procedure CTM 0007]	7.64	6 > pH > 10	Y.
Visible oil/grease (Appearance)	Visual examination [CTM 0176]	PASS	Must be Y / pass on appearance	Y.
Total Organic Carbon	GC and FID [Dow procedure CTM 1144]	< 2.00	Must be less than 10ppm (10 mg/l)	Y.

Date: 14.11.23

Results reviewed and acceptable to discharge? (Y/N): Y.


(if not please follow step 6 onwards in procedure NTW-OPS-PROC-0027)

Quantity to discharge (approx.): 1300mm

Name:



Signature:



Sample Results Print



This report contains details of one or more Sample records. This report was generated using the Print Sample menu option and the 'Sample Results Print' report layout.

Id Numeric	: 2459219
Sample	: SM-13-NOV-2023-669264
Status	: C

Sample Results List

Analysis	Component Name	Type	Result	Units	Status
0176\$OIL/5	Appearance - Oil sheen	O	Pass - No Visible Oil sheen		E
0007\$A/1	pH	N	7.641		E
1144\$B/7	Total Carbon (TC)	N	9.325	mg/liter	E
1144\$B/7	Total Inorganic Carbon (TIC)	N	9.049	mg/liter	E
1144\$B/7	Total Organic carbon (TOC)	K	<2.00	mg/liter	E

