

IQE Silicon Compounds Ltd

RELEASE TO SEWERS

Release summary for 6 months ending 31/12/2023

Operator: IQE Silicon Compounds Ltd

Permit Number: BJ6968IY

Location: St. Mellons

Release Points **S1**

Release points shall be sampled once every six months, and results submitted on a six-month basis

Parameter		
	Suspended Solids mg/l	pH
Maximum	5	8.5
Minimum	19	8
Average	12.00	8.25

Limits: Suspended Solids 400mg/l

pH: between 6 and 11

Signed on behalf of Operator:



Dated: 19/01/2024

Form S1