

Mr Richard Feasey  
The Old Rectory  
Llanfilo  
Brecon  
LD3 0RE

**Your ref: PAN-003919**

**Date: 17/12/2018**

Dear Mr Richard Feasey

**We need more information about your application**

**Application reference: PAN-003919**

**Operator: Mr Richard Feasey**

**Facility: The Old Rectory, Llanfilo, Brecon, LD3 0RE**

Unfortunately the average percolation value calculated during your percolation tests was too low meaning that your infiltration system is too permeable (the Vp is below 15 seconds per mm). Consequently, we require that you include an additional layer of medium on top of your existing infiltration system before we can further process your application. For more guidance on infiltration systems please see the Code of Practice for the design and installation of drainage fields for use in wastewater treatment BS 6297:2007+A1:2008.

We also need to ask you for some more information before we can further process your application. Please could you

- Management system – as per question 3 of the application form, please confirm that you have read the application form guidance and that your management system will meet our requirements.
- Please provide a site plan clearly indicating the location of the septic tank and discharge point to infiltration system. Can you also identify the location of the trial pits used to measure percolation results.

If you need any further advice or information with regards to the above, please contact your local area office. Call 0300 065 3000 and ask to speak to your local area office or your site officer.

Please reply within 10 working days from the date of this letter. If we don't hear from you we must return your application and fee.

If you email or write to us please quote the application reference PAN-003919 on any correspondence and send it to the relevant address below.

Ffôn/Tel 030 0065 3789  
Ffacs/Fax 029 2046 8874  
Ebostr/Email [Tara.al-far@cyfoethnaturiolcymru.gov.uk](mailto:Tara.al-far@cyfoethnaturiolcymru.gov.uk)  
[Tara.al-far@naturalresourceswales.gov.uk](mailto:Tara.al-far@naturalresourceswales.gov.uk)

Canolfan Trwyddedu Cymru (Caerdydd), Cyfoeth Naturiol Cymru, Tŷ Cambria, 29 Heol Casnewydd, Caerdydd. CF24 0TP  
Wales Permitting Centre (Cardiff), Natural Resources Wales, Cambria House, 29 Newport Road, Cardiff. CF24 0TP

Gwefan/Website [www.cyfoethnaturiolcymru.gov.uk](http://www.cyfoethnaturiolcymru.gov.uk)  
[www.naturalresourceswales.gov.uk](http://www.naturalresourceswales.gov.uk)

Croesewir gohebiaeth yn y Gymraeg a'r Saesneg  
Correspondence welcomed in Welsh and English

When we receive the missing items we'll continue to check the details in your application. If there's enough there for us to begin the process of deciding whether or not we can grant your application we say the application is 'duly made' and we'll let you know this by letter.

Please quote our reference if you contact us. If you have any questions please phone me on 030 0065 3789 or email [Tara.al-far@naturalresourceswales.gov.uk](mailto:Tara.al-far@naturalresourceswales.gov.uk).

Yours sincerely

Tara Al-Far