



**Cyfoeth  
Naturiol  
Cymru  
Natural  
Resources  
Wales**

## **Permit with introductory note**

The Environmental Permitting (England & Wales) Regulations 2016

---

**Johnsons Textile Services Limited**

**Johnsons Textile Services Limited, Wrexham  
Aerial Road  
Llay  
Wrexham  
LL12 0TU**

Permit number

**EPR/DB3397ZH**

# Johnsons Textile Services Limited, Wrexham

## Permit number EPR/DB3397ZH

### Introductory note

#### This introductory note does not form a part of the permit

This permit will allow the operator to operate:

- One or more new medium combustion plant (MCP) between 1 and <50MWth but aggregated to <50MWth, which were put in operation on or after 20/12/2018 at a specified location.

The site comprises two 2.1 MWth boilers fired on natural gas, which are classed as new MCPs. Combustion gases (oxides of nitrogen and carbon monoxide) are discharged via 13 m-high exhaust stacks. The MCP are used for generating hot water for the company's hotel and catering linen supply business and does not generate electricity. The MCP are permitted to operate for 2,200 hours per year.

The site is located on an industrial estate in the village of Llay, Wrexham and is associated with hotel and catering linen supply business. There are two protected sites (Llay Bog SSSI and Chwarel Singret SSSI) within 2km of the site. The site is not located in an Air Quality Management Area.

The status log of the permit sets out the permitting history, including any changes to the permit reference number.

<b>Status log of the permit</b>		
<b>Description</b>	<b>Date</b>	<b>Comments</b>
Application PAN-027104	Duly made 29/11/24	Application for Medium Combustion Plant
Permit determined EPR/DB3397ZH/A001	10/01/25	Permit issued to Johnsons Textile Services Limited

End of introductory note

# Permit

The Environmental Permitting (England and Wales) Regulations 2016

Permit number  
**EPR/DB3397ZH**

The Natural Resources Body for Wales (“Natural Resources Wales”) authorises, under regulation 13 of the Environmental Permitting (England and Wales) Regulations 2016

**Johnsons Textile Services Limited** (“the operator”),  
whose registered office is

**Johnson House  
Abbots Park  
Monks Way  
Preston Brook  
Cheshire  
United Kingdom  
WA7 3GH**

company registration number **00464645**

to operate one or more Medium Combustion Plant and/or Specified Generators at

Johnsons Textile Services Limited, Wrexham  
Aerial Road  
Llay  
Wrexham  
LL12 0TU

to the extent authorised by and subject to the conditions of this permit.

Signed	Date
<b>Holly Noble</b>	<b>10/01/2025</b>

Authorised on behalf of Natural Resources Wales

# Conditions

## 1 Management

### 1.1 General management

- 1.1.1 The operator shall manage and operate the activities:
- (a) in accordance with a written management system that identifies and minimises risks of pollution, so far as is reasonably practicable, including those arising from operations, maintenance, accidents, incidents, non-conformances, closure and those drawn to the attention of the operator as a result of complaints; and
  - (b) using sufficient competent persons and resources.
- 1.1.2 Records demonstrating compliance with condition 1.1.1 shall be maintained.
- 1.1.3 Any person having duties that are or may be affected by the matters set out in this permit shall have convenient access to a copy of it kept at or near the place where those duties are carried out.

## 2 Operations

### 2.1 Permitted activities

- 2.1.1 The operator is only authorised to carry out the activities specified in schedule 1, table S1.1 (the "activities").

### 2.2 The site

- 2.2.1 No MCP shall be operated beyond the site of the grid reference specified for it in schedule 1, table S1.1 of the permit.

### 2.3 Operating techniques

- 2.3.1 The activities shall be operated using the techniques and, in the manner, described in schedule 1, table S1.2.

## 3 Emissions and monitoring

### 3.1 Emissions to air

- 3.1.1 There shall be no point source emissions to air except from the sources and emission points listed in schedule 3, table S3.1.
- 3.1.2 The limits given in schedule 3 shall not be exceeded.

### 3.2 Monitoring

- 3.2.1 The operator shall, unless otherwise agreed in writing by Natural Resources Wales, undertake the monitoring specified in the following tables in schedule 3 to this permit, or at a greater frequency if notified to the operator in writing by Natural Resources Wales:
- (a) point source emissions specified in table S3.1.
- 3.2.2 Monitoring shall not take place during periods of start up or shut down.

- 3.2.3 For the following activities referenced in schedule 1, table S1.1 the first monitoring measurements shall be carried out
- (a) For new MCP within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later.
- 3.2.4 The operator shall maintain records of all monitoring including records of the taking and analysis of samples, instrument measurements (periodic and continual), calibrations, examinations, test and surveys and any assessment or evaluation made on the basis of such data.

## **4 Information**

### **4.1 Records**

- 4.1.1 All records required to be made by this permit shall:
- (a) be legible;
  - (b) be made as soon as reasonably practicable;
  - (c) if amended, be amended in such a way that the original and any subsequent amendments remain legible, or are capable of retrieval; and
  - (d) be retained, unless otherwise agreed in writing by Natural Resources Wales, for at least 6 years from the date when the records were made.
- 4.1.2 The operator shall maintain convenient access, in either electronic or hard copy, to the records, plans and management system required to be maintained by this permit.
- 4.1.3 The operator shall maintain a record of the type and quantity of fuel used and the total annual hours of operation for each MCP and/or Specified Generator.
- 4.1.4 The operator shall maintain a record of any events of non-compliance and the measures taken to ensure compliance is restored in the shortest possible time

### **4.2 Reporting**

- 4.2.1 The operator shall send all reports and notifications required by the permit to Natural Resources Wales using the contact details supplied in writing by Natural Resources Wales.
- 4.2.2 Within 28 days of the end of the reporting period the operator shall, unless otherwise agreed in writing by Natural Resources Wales, submit reports of the monitoring and assessment carried out in accordance with the conditions of this permit, as follows:
- (a) in respect of the parameters and emission points specified in schedule 4, table S4.1;
  - (b) for the reporting periods specified in schedule 4, table S4.1 and using the forms specified in schedule 4, table S4.2; and
  - (c) giving the information from such results as required by the forms specified in those tables.

### **4.3 Notifications**

- 4.3.1 In the event:
- (a) of a breach of any of the permit conditions the operator must immediately—
    - (i) inform Natural Resources Wales, and
    - (ii) take the measures necessary to ensure that compliance is restored within the shortest possible time;

- (b) of a breach of any of the permit conditions which causes a significant degradation of local air quality, the operator must immediately suspend the operation of the activities or the relevant part of them until compliance with the conditions has been restored.
- 4.3.2 Any information provided under condition 4.3.1 shall be confirmed by sending the information listed in schedule 5 to this permit within the time period specified in that schedule.
- 4.3.3 Where Natural Resources Wales has requested in writing that it shall be notified when the operator is to undertake monitoring and/or spot sampling, the operator shall inform Natural Resources Wales when the relevant monitoring and/or spot sampling is to take place. The operator shall provide this information to Natural Resources Wales at least 14 days before the date the monitoring is to be undertaken.
- 4.3.4 Natural Resources Wales shall be notified within 14 days of the occurrence of the following matters, except where such disclosure is prohibited by Stock Exchange rules:
- Where the operator is a registered company:
- (a) any change in the operator's trading name, registered name or registered office address; and
  - (b) any steps taken with a view to the operator going into administration, entering into a company voluntary arrangement or being wound up.
- Where the operator is a corporate body other than a registered company:
- (c) any change in the operator's name or address; and
  - (d) any steps taken with a view to the dissolution of the operator.
- In any other case:
- (e) the death of any of the named operators (where the operator consists of more than one named individual);
  - (f) any change in the operator's name(s) or address(es); and
  - (g) any steps taken with a view to the operator, or any one of them, going into bankruptcy, entering into a composition or arrangement with creditors, or, in the case of them being in a partnership, dissolving the partnership.

## 4.4 Interpretation

- 4.4.1 In this permit the expressions listed in schedule 6 shall have the meaning given in that schedule.
- 4.4.2 In this permit references to reports and notifications mean written reports and notifications, except where reference is made to notification being made "immediately", in which case it may be provided by telephone.

# Schedule 1 – Operations

**Table S1.1 activities**

National Grid Reference and or activity reference/ emission point	Activity listed in the EP Regulations	Description of Medium Combustion Plant and/or Specified Generator	Fuel	Operating hours limit per year
Site Centre NGR: 332904, 356154 A1, unique identifier: 332915 356168 A2, unique identifier: 332920, 356162	Schedule 25A – Medium Combustion Plant as detailed in Schedule 7	2x 2.1 MWth boiler	Natural gas	2,200 per boiler

**Table S1.2 Operating techniques for Medium Combustion Plant as detailed in Schedule 7**

**Description**

Each MCP must be operated in accordance with the manufacturer's instructions and records must be made and retained to demonstrate this

The operator must keep periods of start-up and shut-down of each MCP as short as possible

There must be no persistent emission of 'dark smoke' as defined in section 3(1) of the Clean Air Act 1993

## **Schedule 2 – Waste types, raw materials and fuels**

This schedule is not used.

## Schedule 3 – Emissions and monitoring

**Table S3.1 Point source emissions to air – emission limits and monitoring requirements**

Emission point reference & location	Source/technology	Parameter	Limit (including unit)	Reference period	Monitoring frequency	Monitoring standard or method <sup>Note 1</sup>
A1	New medium combustion plant other than engines and gas turbines fuelled on natural gas	Oxides of Nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	100 Nmg/m <sup>3</sup>	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators	Within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later  then  Every 3 years	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators
		Carbon monoxide	No limit set	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators	Within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later  then  Every 3 years	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators

A2	Oxides of Nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	100 Nmg/m <sup>3</sup>	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators	Within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later then Every 3 years	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators
	Carbon monoxide	No limit set	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators	Within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later then Every 3 years	In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators

Note 1: Monitoring requirements are defined at a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases at a standardised O<sub>2</sub> content of 6 % for solid fuels, 15 % for engines and gas turbines and 3 % all other MCPs

## Schedule 4 – Reporting

Parameters, for which reports shall be made, in accordance with conditions of this permit, are listed below.

**Table S4.1 Reporting of monitoring data**

Parameter	Emission or monitoring point/reference	Reporting period	Period begins
Emissions to air Parameters as required by condition 3.2.1.	A1	Within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later  then  Every 3 years	1 January
Emissions to air Parameters as required by condition 3.2.1.	A2	Within four months of the issue date of the permit or the date when the MCP is first put into operation, whichever is later  then  Every 3 years	1 January

**Table S4.2 Reporting forms**

Media/parameter	Reporting format	Date of form
Air	Form air 1 or other form as agreed in writing by Natural Resources Wales	DD/MM/YY

# Schedule 5 – Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

## Part A

Permit Number	
Name of operator	
Location of Facility	
Time and date of the detection	

<b>(a) Notification requirements for any malfunction, breakdown or failure of equipment or techniques, accident, or emission of a substance not controlled by an emission limit which has caused, is causing or may cause significant pollution</b>	
<b>To be notified within 24 hours of detection</b>	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substances(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident.	

<b>(b) Notification requirements for the breach of a limit</b>	
<b>To be notified within 24 hours of detection unless otherwise specified below</b>	
Emission point reference/ source	
Parameter(s)	
Limit	

<b>(b) Notification requirements for the breach of a limit</b>	
<b>To be notified within 24 hours of detection unless otherwise specified below</b>	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

<b>Time periods for notification following detection of a breach of a limit</b>	
<b>Parameter</b>	<b>Notification period</b>

<b>(c) Notification requirements for the detection of any significant adverse environmental effect</b>	
<b>To be notified within 24 hours of detection</b>	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

## Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	
Post	
Signature	
Date	

\* authorised to sign on behalf of the operator

## Schedule 6 – Interpretation

“accident” means an accident that may result in pollution.

“application” means the application for this permit, together with any additional information supplied by the operator as part of the application and any response to a notice served under Schedule 5 to the EP Regulations.

“authorised officer” means any person authorised by Natural Resources Wales under section 108(1) of The Environment Act 1995 to exercise, in accordance with the terms of any such authorisation, any power specified in section 108(4) of that Act.

“EP Regulations” means The Environmental Permitting (England and Wales) Regulations SI 2016 No.1154 and words and expressions used in this permit which are also used in the Regulations have the same meanings as in those Regulations.

“first put into operation” means that the plant must have been fired with its design fuel up to its full load. This can be, but does not have to be, during commissioning.

“medium combustion plant” or “MCP” means a combustion plant with a rated thermal input equal to or greater than 1 MW but less than 50 MW.

“Medium Combustion Plant Directive” or “MCPD” means Directive 2015/2193/EU of the European Parliament and of the Council on the limitation of emissions of certain pollutants into the air from medium combustion plants.

“new MCP” means an MCP first put into operation on or after 20/12/2018.

“operating hours” means the time, expressed in hours, during which a combustion plant is operating and discharging emissions into the air, excluding start-up and shut-down periods.

“quarter” means a calendar year quarter commencing on 1 January, 1 April, 1 July or 1 October.

“year” means calendar year ending 31 December.

## Schedule 7 – Annex I of MCPD

<b>MCP Identifier</b>	A1, A2
<b>1. Rated thermal input (MW) of the medium combustion plant.</b>	2.1 MWth each (4.2 MWth combined)
<b>2. Type of the medium combustion plant (diesel engine, gas turbine, dual fuel engine, other engine or other medium combustion plant).</b>	Natural gas boiler
<b>3. Type and share of fuels used according to the fuel categories laid down in Annex II.</b>	100% natural gas
<b>4. Date of the start of the operation of the medium combustion plant or, where the exact date of the start of the operation is unknown, proof of the fact that the operation started before 20 December 2018.</b>	Scheduled for 01/02/2025
<b>5. Sector of activity of the medium combustion plant or the facility in which it is applied (NACE code).</b>	S96.0.1 - Washing and (dry-)cleaning of textile and fur products
<b>6. Expected number of annual operating hours of the medium combustion plant and average load in use.</b>	2,200 hours of operation per boiler per year Average load in use is 100%
<b>7. Where the option of exemption under Article 6(3) or Article 6(8) is used, a declaration signed by the operator that the medium combustion plant will not be operated more than the number of hours referred to in those paragraphs.</b>	Not applicable
<b>8. Name and registered office of the operator and, in the case of stationary medium combustion plants, the address where the plant is located.</b>	Johnsons Textile Services Limited <u>Registered Office Address</u> Johnson House Abbots Park Monks Way Preston Brook Cheshire United Kingdom WA7 3GH <u>Plant Location</u> Johnsons Textile Services Limited, Wrexham Aerial Road Llay Wrexham LL12 0TU

END OF PERMIT

Permit Number: DB3397ZH

Operator: Johnsons Textile Services Limited

Facility: Johnsons Textile Services Limited, Wrexham

Form Number: Air1 / 10/01/25

Reporting of emissions to air for the period from DD/MM/YYYY to DD/MM/YYYY

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result <sup>[1]</sup>	Test Method <sup>[2][5]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
A1	Oxides of Nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	100 mg/Nm <sup>3</sup>	Periodic		In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators		
	Carbon monoxide	No limit set	Periodic		In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators		

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result <sup>[1]</sup>	Test Method <sup>[2][5]</sup>	Sample Date and Times <sup>[3]</sup>	Uncertainty <sup>[4]</sup>
A2	Oxides of Nitrogen (NO and NO <sub>2</sub> expressed as NO <sub>2</sub> )	100 mg/Nm <sup>3</sup>	Periodic		In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators		
	Carbon monoxide	No limit set	Periodic		In line with web guide: Monitoring stack emissions: low risk MCPs and specified generators		

- [1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.
- [2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.
- [3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.
- [4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.
- [5] Monitoring requirements are defined at a temperature of 273.15 K, a pressure of 101.3 kPa and after correction for the water vapour content of the waste gases at a standardised O<sub>2</sub> content of 6 % for solid fuels, 15 % for engines and gas turbines and 3 % all other MCPs

Signed .....

Date.....