

Permit Number: CB3895HY

Operator: Vantage Data Centers UK Limited

Facility: CWL13 Data Centre


Form Number: Performance 1 / 31/01/2024

Reporting of other performance indicators for the year 2023

Parameter	Units
Total diesel used	0 tonnes
Total Hydrotreated Vegetable oil (HFO) used	1.2 tonnes (Note 2)
Total other fuel (state, if applicable.....) used	N/A
Generator operation for maintenance/testing: Total hours for the site	5 hours 12 minutes
Generator operation for maintenance/testing: Per generator <ul style="list-style-type: none"> Total hours Total number of runs Number of minutes per run <p>To be reported annually by the operator on an appropriate table / spreadsheet as agreed by Natural Resources Wales</p>	See spreadsheet attached for information on individual generators, including: Hours Number if runs Minutes per run
Generator operating during emergency scenario: <ul style="list-style-type: none"> Total duration of emergency runs/events Total number of emergency runs/events Per run, number of engines and thermal capacity deployed <p>To be reported annually by the operator on an appropriate table / spreadsheet as agreed by Natural Resources Wales</p>	No emergency operation of generators in this period.

Operator's comments :

- CWL13 generators were commissioned and available (in standby) from August 2023.
- HVO usage calculated from generator running hours and assuming operation at 100% load.

Signed 
 (Authorised to sign as representative of Vantage Data Centres UK Limited)

Date ...02-02-2024.....