

Generator emergency scenario – to be provided within 24 hours of emergency operation

Permit Number: **EPR/BB3599CW**
 Facility: **Newport Data Centre**

Operator: **Vantage Data Centers UK**
 Form Number: **Limited**
Emergency Scenario / 22/04/2020

Reporting of generator emergency scenario operation

Parameter	
Date of emergency operation	10/02/2023
Time of emergency operation	XX:XX
Number of generators operating immediately after the emergency operation	8
Number of generators operating 2 hours after emergency operation	8
Anticipated duration of the mains supply emergency operation	Momentary loss of supply to cell GF19

Operator's comments:

Emergency run due to momentary loss of supply.

Signed
 (Authorised to sign as representative of Operator)

Date...27/02/2024.....



KR...
👤

Start time is required. We only have the date from the running hours reports.

@mention or reply

KR...
👤

From running hours report, all 8 generators in this cell ran for more than 2 hours. (2:21 - 2:36)

@mention or reply