

Permit Reference Number : BX3376IG

Operator : Continental Teves UK Limited

Installation : Continental Teves UK Limited

Form Number : S1

Reporting of Emissions to Sewer for the period from 01.10.2024 to 31.12.2024

| Emission Point | Substance / Parameter | Emission Limit Value | Result ^[1] | Test Method ^[2] | Sample Date and Times ^[3] | Accreditation/ Certification ^[4] | Uncertainty ^[5] |
|----------------|----------------------------|----------------------|-----------------------|----------------------------------|--------------------------------------|---|----------------------------|
| S1 | pH | 6-11 | Max 9.8 Min 9.0 | Plant & Lab Meters | 11.12.2024 14.10.24 | N/A | N/A |
| S1 | Chromium and its compounds | 1 mg/l | 0.73 mg/l | Atomic Absorption | 18.10.2024 | N/A | N/A |
| S1 | Zinc and its compounds | 2 mg/l | 1.50 mg/l | Atomic Absorption | 22.10.2024 | N/A | N/A |
| S1 | Nickel and its compounds | 2 mg/l | 0.50 mg/l | Atomic Absorption | 26.11.2024 | N/A | N/A |
| S1 | Total flow | | 1450 m3 | Ultrasonic Flow Meter at Outfall | 01.10.2024 to 31.12.2024 | M/CERTS | 4.16% |

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with the Agency is used, then the appropriate identifier is given. In other cases the principal technique is stated, e.g. colorimetry.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements, or flow/time proportional samples, the percentage of the process operating time covered by the monitoring is given.

[4] The accreditation status of the equipment and/or the monitoring organisation, as appropriate, for the methods used for both sampling and analysis.

[5] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated. The following uncertainties are quoted on a different basis (basis as stated) – *{The basis of any other uncertainty figure needs to be stated. Where no figure is available the Agency will need to agree an appropriate uncertainty value.}*

Signed



Date: 02.01.2025.