

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01.10.23 – 31.10.23**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	8.01	16.10.23	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	24.9	16.10.23	BS EN 872
W1	Oil or Grease	None Present	None Visible	16.10.23	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed [REDACTED] Date : 03.11.23
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01.11.23 – 30.11.23**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.85	17.11.23	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	24.4	17.11.23	BS EN 872
W1	Oil or Grease	None Present	None Visible	17.11.23	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : XXXXXXXXXX Date : 01.12.23
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)

Permit Reference Number: BL3986ID

Operator: Tarmac Cement & Lime Ltd

Installation: Aberthaw Works

Form Number: Water 1 / 19/07/16

**Quarterly Reporting of Emissions to Surface Water – Emission Points W1 & W2
for the period 01.12.23 – 31.12.23**

Emission Point	Parameter	Emission Limit Value	Result	Date of Measurement	Method
W1	pH (minimum)	6	7.91	15.12.23	BS ISO10523
W1	pH (maximum)	9	-	-	BS ISO10523
W1	Total Suspended Solids (Maximum)	50 mg/l	4.15	15.12.23	BS EN 872
W1	Oil or Grease	None Present	None Visible	15.12.23	Visual Check
W2	pH (minimum)	6	-	-	BS ISO10523
W2	pH (maximum)	9	-	-	BS ISO10523
W2	Total Suspended Solids (Maximum)	50 mg/l	-	-	BS EN 872
W2	Oil or Grease	None Present	-	-	Visual Check

Signed : XXXXXXXXXX Date : 02.01.24
(Authorised to sign as representative of Tarmac Cement & Lime Ltd)