

Date	Suspended solids mg/l	Dissolved solids mg/l	Oil and grease mg/l	Copper mg/l	Lead as Pb mg/l	Tin as Sn mg/l	Zinc as Zn mg/l	Aluminium as Al mg/l	Mercury mg/l	Arsenic mg/l	Nickel as Ni mg/l	Nitrogen mg/l	pH max	pH min	Comments
28.10.2024	4 mg/l	782 mg/l	<1mg/l	0.0032mg/l	<0.0003mg/l	<0.0015mg/l	<0.006mg/l	0.183mg/l	<0.00001mg/l	0.00282mg/l	<0.0010mg/l	0.41mg/l	7.6	7.6	
Nov-24															Unable to obtain a sample.
27.12.2024 15:32pm													8		HR / HSE Manager attended site to take sample, insufficient quantity available, 8 PH only.
Permit Limit	50mg/l	1200mg/l	10mg/l	0.25mg/l	0.1mg/l	0.1mg/l	0.5mg/l	1.5mg/l	0.075mg/l	0.1mg/l	0.5mg/l	1.5mg/l	9	6	

EP3935UC
Swan Alloy UK Ltd
Water (WA1)