

Schedule 5 - Notification

These pages outline the information that the Operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/NP3030BJ
Name of Operator	EnerSys Ltd; Newport
Location of facility	Stephenson Street
Time and date of the emission	

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment

To be notified immediately	
Date and time of the event	
Reference or description of the location of the event	
Description of where any release into the environment took place	
Substance(s) potentially released	
Best estimate of the quantity or rate of release of substances	
Measures taken, or intended to be taken, to stop any emission	
Description of the failure or accident	

(b) Notification requirements for the breach of a permit condition

To be notified immediately	
Emission point reference/source	S1
Parameter(s)	Continuous monitoring of flow
Limit	150,000l/day
Measured value and uncertainty	N/A
Date and time of monitoring	13/05/24 10:00
Measures taken, or intended to be taken, to stop the emission	No discharge was made through emission point S1 on the 13 th and 14 th May as there was not a way of measuring flow data. Engineers are looking at the millitronics device to try and get it back online. Until a flow measuring device is back in place, discharges will take place a full tank at a time so that discharge can be recorded, (roughly 10,000l per full tank).

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified immediately	
Description of where the effect on the environment was detected	
Substance(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B – to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	The flow meter was old and had reached the end of its life, (at least 15 years old).
Measures taken, or intended to be taken, to prevent a recurrence of the incident	A new MCERTS approved flow meter will be installed and inspected by an MCERTS inspector
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	Until the new flow meter is installed, release from S1 will only be done in full tanks of 10,000L to allow the volume of discharge to be monitored and recorded.
The dates of any unauthorised emissions from the facility in the preceding 24 months.	None

Name*	
Post	Environmental Lead
Signature	
Date	12/06/24

* authorised to sign on behalf of Enersys Newport Lt