

Permit Number: EPR/GP3692LQ

Operator: RMR Sand And Aggregates Ltd

Facility: The Construction Hub

Form Number: Water 1

Reporting of emissions to water (other than to sewer) and land for the period from 01/01/2024 to 30/06/2024

Emission Point	Substance / Parameter	Emission Limit Value	Reference Period	Result ^[1]	Test Method ^[2]	Sample Date and Times ^[3]	Uncertainty ^[4]
W1	Total suspended solids	50ml/L	6 Months	<7 MG/L	2704	17/06/24	
W1	Oils and Grease	No visible oil or grease	Weekly	None Visible	Visual	17/06/24	
W1	Copper	No emissions limit	6 Months	<0.1 MG/L	2973	17/06/24	
	Iron	No emissions limit	6 Months	0.6 mg/l	2973	17/06/24	
	Lead	No emissions limit	6 Months	<0.3 mg/l	2973	17/06/24	
	Zinc	No emissions limit	6 Months	<0.01 mg/l	2973	17/06/24	
W1	Ammoniacal Nitrogen	No emissions limit	6 Months	<1.0 mg/l	2550	17/06/24	

[1] The result given is the maximum value (or the minimum value in the case of a limit that is expressed as a minimum) obtained during the reporting period, expressed in the same terms as the emission limit value. Where the emission limit value is expressed as a range, the result is given as the 'minimum – maximum' measured values.

[2] Where an internationally recognised standard test method is used the reference number is given. Where another method that has been formally agreed with Natural Resources Wales is used, then the appropriate identifier is given. In other cases the principal technique is stated, for example gas chromatography.

[3] For non-continuous measurements the date and time of the sample that produced the result is given. For continuous measurements the percentage of the process operating time covered by the result is given.

[4] The uncertainty associated with the quoted result at the 95% confidence interval, unless otherwise stated.

Signed
(Authorised to sign as representative of Operator)

Date: 17/06/2024