

Schedule 1 – 5.1.1 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	Therminol 3 '402' Biphenyl Tank
Time and date of the emission:	19/04/2020

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Biphenyl vapour	Discharge to Air	Discharge from Conservation Vent <30kg of vapour	15:00 – 15:30

Description of the failure or accident, and... Measures taken, or intended to be taken, to stop the emission:	Upon identification of that a release was occurring (resulting from a pipe-blockage related over-pressure and unseated CV), the plant was immediately shut down, and a water monitor activated as a precautionary measure The release quantity was relatively small, being less than; process safety & internal reporting thresholds, but is none-the-less being Notified due to being a process malfunction with potential odour impact Further detail to follow in the Part B
--	--

* Signed:



Date: 20/04/2020

* authorised to sign on behalf of Solutia UK Ltd