

Schedule 5 Notification

PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	A4 Boiler 16
Time and date of the emission:	16/06/2023 [13:30 – 14:30], and 26/10/23 [11:10 – 12:10]

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Carbon Monoxide	Atmosphere	Measured CO concentrations of; 117 (+/- 4.4) mg/Nm3 and 176 (+/-6.8) mg/Nm3 Vs 100 mg/Nm3 limit (at specified reference conditions)	As above

Description of the failure or accident, and... Measures taken, or intended to be taken, to stop the emission:	With reference to previous Part A Notification submission for the 16/06/2023 (details included here for completeness); Monitoring report(s) received following statutory emissions monitoring, which indicated elevated CO (Carbon Monoxide) in the combined Boiler & Gas Turbine exhaust at the time of the monitoring exercise Further information to follow in Part B
--	---

* Signed:



Date: 12/12/2023

* authorised to sign on behalf of Solutia UK Ltd