

Schedule 5 Notification


PART A

Permit Number:	BR9715B
Name of Operator:	Solutia UK Ltd
Location of Installation:	Corporation Road, Newport, Gwent, NP194XF
Location of the emission:	W1 Effluent
Time and date of the emission:	Week ending 14/12/23

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
Formaldehyde	Effluent	Concentration in effluent: 13.1 mg/l Vs 10.0 mg/l limit	Weekly Composite Sample 07 th – 14 th December 23

Description of the failure or accident, and... Measures taken, or intended to be taken, to stop the emission:	The weekly 'W1' effluent composite sample resulted in an observed concentration of formaldehyde in excess of the permitted discharge limit for the week This is as a result of an issue on the Dequest Amino plant scrub-water tank – which has since been resolved Further information to follow in Part B
--	---

* Signed:



Date: 14/12/2023

* authorised to sign on behalf of Solutia UK Ltd