

## Schedule 5 Notification


### PART A

<b>Permit Number:</b>	BR9715B
<b>Name of Operator:</b>	Solutia UK Ltd
<b>Location of Installation:</b>	Corporation Road, Newport, Gwent, NP194XF
<b>Location of the emission:</b>	Site Effluent Discharge W1
<b>Time and date of the emission:</b>	Composite Sample w/e; 25/10/2024

Substance(s) emitted	Media e.g. air /water	Best estimate of the quantity or the rate of emission	Time during which the emission took place
PCB in site effluent	Estuary	152g/wk Vs the Permitted limit of 100g/wk	As above

<b>Description of the failure or accident, and...</b>	The composite effluent sample taken during the weekly period mentioned, indicates an excursion of the permit limit for PCBs
<b>Measures taken, or intended to be taken, to stop the emission:</b>	Investigation into possible cause(s) ongoing. Further information to follow in Part B

\* Signed:



Date: 28/10/2024

\* authorised to sign on behalf of Solutia UK Ltd