

Schedule 5 Notification

PART A

| | |
|---------------------------------------|---|
| Permit Number: | BR9715B |
| Name of Operator: | Solutia UK Ltd |
| Location of Installation: | Corporation Road, Newport, Gwent, NP194XF |
| Location of the emission: | Site Effluent Discharge W1 |
| Time and date of the emission: | Composite Sample w/e; 5/12/2024 |

| Substance(s) emitted | Media e.g. air /water | Best estimate of the quantity or the rate of emission | Time during which the emission took place |
|----------------------|-----------------------|---|---|
| PCB in site effluent | Estuary | 172 g/week Vs the Permitted limit of 100 g/week | As above |

| | |
|---|--|
| <p>Description of the failure or accident, and...</p> <p>Measures taken, or intended to be taken, to stop the emission:</p> | <p>The composite effluent sample taken during the weekly period indicates an excursion of the permit limit for PCBs</p> <p>This was caused by work to repair the underground surface water system next to the warehouse which is located to the South of a PCB contaminated area, the work involved an excavation.</p> <p>Collection of groundwater into IBC's was occurring throughout the work, this did not prevent the exceedance.</p> <p>The repairs to the underground system started 25th November and finished 5th December.</p> <p>Further investigation into cause ongoing. Further information to follow in Part B.</p> |
|---|--|

* Signed: 

Date: 10/12/2024

* authorised to sign on behalf of Solutia UK Ltd