

Project Ref: 449

Project: Sirior Bach Caravan Park

Date: 11.02.25

Woodlands A and The Retreat - Outfall A

Source of Waste				Flow Litre / Day		BOD Grams / Day		NH3	
Description	No of units	Occupancy	Total	Per Head	Total	Per Head	Total	Per Head	Total
Static Fully Serviced	111	2	222	150	33300	60	13320	8	1776
TOTAL LOAD			222		33300		13320		1776
Average Daily Flow (l/s)	0.39								
m3/day	33.3								
Reduction Factor 0.8 - m3/day	26.6								

Complete Form B6