



**Cyfoeth
Naturiol
Cymru
Natural
Resources
Wales**

COED Y MWSTWR HOTEL
MANAGING DIRECTOR
COED Y MWSTWR HOTEL
COYCHURCH
BRIDGEND

CF35 6AF

Our ref: BP0046701

Your ref:

Date: 22nd September 2017

Dear Ms Hancock

Environmental Permitting (England and Wales) Regulations 2016

Failure to Comply with Permit Condition

Samples taken from Coed y Mwstwr Hotel STW on the 14th July, 3rd August and 29th August 2017

The attached analytical report indicates that samples taken of the discharge from Coed y Mwstwr Hotel STW on the 14th July, 3rd August and 29th August 2017 for which you hold the permit, exceeded the permitted limits.

These results, together with all other results taken for the purpose of permit monitoring, will form part of the public register held by Natural Resources Wales and are available for inspection by any member of the public.

Please let me know within fourteen days the reason for these failures and the steps that you intend to take or have taken to prevent recurrence. I shall have regard to your response when determining what further action we may take to ensure compliance with the consent.

These failures follow 2 other failures that occurred in April and May 2017. Following these failures I met with your Deputy Manager and Contractor on site. During the visit it became apparent that a significant quantity of surface water was entering the sewage system this is likely to adversely impact the operation of your package plant. We discussed the issues and agreed that investigations would be undertaken and plans drawn up to remediate the situation. Following these further failures I would request that you submit these plans together with a timetable for any works that need to be carried out so that you comply with your permit conditions.

Maes Newydd, Llandarcy, Neath Port Talbot, SA10 6JQ.
Customer services line: 03000 0653000
Email: enquiries@naturalresourceswales.gov.uk
www.naturalresourceswales.gov.uk

Yours sincerely

A handwritten signature in black ink, appearing to read 'Pippa Sabine', with a stylized, cursive script.

Pippa Sabine
Environment Officer

Tel:- 03000 653303

E-Mail:- pippa.sabine@cyfoethnaturiolcymru.gov.uk

Measuring program	Station	Label	Time stamp (Sampling)	Status	Sampling staff	Sample Source	0076 / Temp Water / Field [°C]	0085 / BOD ATU / Low [mg/l]	0135 / Sld Sus@105C / Low [mg/l]	Sign
NRW_WI MS	COED-Y-									
	MWSTWR									
	HOTEL	170055708 / 1 / 1			P683 - KATE	38274-NRW LLANELLI				
	STW F.E	(Replicate 0)	28/04/2017 14:15	Confirmed	THOMAS	LABORATORY	17.7	25.1	105 N	
NRW_WI MS	COED-Y-									
	MWSTWR									
	HOTEL	170082708 / 1 / 1			P683 - KATE	38274-NRW LLANELLI				
	STW F.E	(Replicate 0)	09/05/2017 12:13	Confirmed	THOMAS	LABORATORY	18.2	1.63	63 N	
NRW_WI MS	COED-Y-									
	MWSTWR									
	HOTEL	170105408 / 1 / 1			P683 - KATE	38274-NRW LLANELLI				
	STW F.E	(Replicate 0)	08/06/2017 13:07	Confirmed	THOMAS	LABORATORY	19.8		17.5 N	
NRW_WI MS	COED-Y-									
	MWSTWR									
	HOTEL	170128308 / 1 / 1			P683 - KATE	38274-NRW LLANELLI				
	STW F.E	(Replicate 0)	14/07/2017 14:40	Confirmed	THOMAS	LABORATORY	22.2	12.2	66.5 N	
NRW_WI MS	COED-Y-									
	MWSTWR									
	HOTEL	170174708 / 1 / 1			P683 - KATE	38274-NRW LLANELLI				
	STW F.E	(Replicate 0)	03/08/2017 14:09	Confirmed	THOMAS	LABORATORY	21.6	12.9	58 N	
NRW_WI MS	COED-Y-									
	MWSTWR									
	HOTEL	170172508 / 1 / 1			P683 - KATE	38274-NRW LLANELLI				
	STW F.E	(Replicate 0)	29/08/2017 14:39	Confirmed	THOMAS	LABORATORY	22.4	30.5	72 N	

