

REGISTER OF CONDITIONS

AND OTHER TERMS

IMPOSED UNDER SECTION 7 OF THE RIVERS (PREVENTION OF POLLUTION) ACT, 1951
(AS APPLIED BY THE CLEAN RIVERS (ESTUARIES AND TIDAL WATERS) ACT, 1960)
AND THE RIVERS (PREVENTION OF POLLUTION) ACT, 1961.

No. 774

CV/34/1

CAT. No. R.B.12 SHAW & SONS LTD., FLETTER LONDON, E.C.4.

DATE ON WHICH CONDITION CAME INTO FORCE AND PERIOD OF EFFECT	FULL ADDRESS OR OTHER SUFFICIENT DESCRIPTION OF LAND OR PREMISES TO WHICH THE TERM OR CONDITION RELATES	
Conditions become effective from date of initial discharge.	LLANFAIRFECHAN SEWERAGE AND SEWAGE DISPOSAL SCHEME - STORM SEWAGE DISCHARGES	
USE OF NEW OR ALTERED OUTLETS		DISCHARGE OF TRADE SEWAGE EFFLUENT
<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(I) PRECISE LOCATION OF OUTLET As stated in Consent.</p> <p>(II) CONSTRUCTION OF OUTLET (OTHER THAN CONDITIONS TO BE SATISFIED BEFORE OUTLET IS BROUGHT INTO USE)</p> <p>(III) USE OF OUTLET</p> <p>(IV) USE OF ANY OTHER OUTLET FOR TRADE OR SEWAGE EFFLUENT FROM THE SAME LAND OR PREMISES</p>		<p>CONDITIONS IMPOSED WITH RESPECT TO:-</p> <p>(I) NATURE AND COMPOSITION OF DISCHARGE</p> <p>Storm Sewage in excess of 6 x D.W.F. in the sewer entering the storm overflow chamber in respect of S.O. No. 1 and S.O. No. 2. Storm sewage in excess of 18 x D.W.F. in the sewer entering the storm overflow chamber in respect of S.O. No. 3.</p> <p>(II) TEMPERATURE OF DISCHARGE</p> <p>(III) VOLUME OR RATE OF DISCHARGE OF EFFLUENT FROM LAND OR PREMISES</p> <p>* (IV) PROVISION OF FACILITIES FOR TAKING SAMPLES</p> <p>* (V) DATE OF EXPIRATION OF PERIOD SPECIFIED UNDER S-5(2) OF 1961 ACT</p> <p>1st January, 1972.</p>
REMARKS-		REMARKS-

C.203/B. CV/34/1. AJ/AJ.

31st October, 1969.

Dear Sir,

Rivers (Prevention of Pollution) Acts 1951 - 1961
Llanfairfechan Sewerage and Sewage Disposal Scheme
Discharges of Storm Sewage

With reference to your application of 4th August 1969, the Gwynedd River Authority, in pursuance of their powers under the above Acts, hereby consent to the bringing into use of new outlets for the discharge of storm sewage and the making of new discharges of storm sewage into the watercourses mentioned hereunder in accordance with the plans submitted.

- S.O. No. 1. Afon Llanfairfechan on its right bank 40 yards upstream of Pont Newydd (A.55) when the flow in the sewer entering the storm overflow chamber exceeds 6 x D.W.F. GR SH 68137475
- S.O. No. 2. Afon Llanfairfechan on its right bank 100 yards downstream of railway bridge when the flow in the sewer entering the storm overflow chamber exceeds 6 x D.W.F. GR SH 67917537
- S.O. No. 3. Menai Strait foreshore below Garistia when the flow in the sewer entering the storm overflow chamber exceeds 18 x D.W.F. GR SH 69327606

Subject to the discharge being screened or suitably baffled to prevent the discharge of solid matter and restricted to those flows in excess of six times dry weather flow in respect of storm overflows Nos. 1 and 2 and to flow in excess of 18 times dry weather flow in respect of storm overflow No. 3.

The terms of this consent will not, without the consent in writing of the person to whom this consent is given (or his successor), be altered before the expiration of the period ending with the 1st January 1972.

Yours faithfully,



Clerk of the Authority

The Clerk,
Llanfairfechan Urban District Council,
Council Offices,
LLANFAIRFECHAN,
Caerns.