

449

Project:

Sirior Bach Caravan Park

Date:

11.02.25

Woodlands B - Outfall B

Source of Waste				Flow Litre / Day		BOD Grams / Day		NH3	
Description	No of units	Occupancy	Total	Per Head	Total	Per Head	Total	Per Head	Total
Static Fully Serviced	25	2	50	150	7500	60	30000	8	4000
TOTAL LOAD (S)			50		7500		3000		400
Average Daily Flow (l/s)	0.09								
m3/day	7.5								
Reduction Factor 0.8 - m3/day	6.0								