

Schedule 5 Notification

These pages outline the information that the operator must provide.

Units of measurement used in information supplied under Part A and B requirements shall be appropriate to the circumstances of the emission. Where appropriate, a comparison should be made of actual emissions and authorised emission limits.

If any information is considered commercially confidential, it should be separated from non-confidential information, supplied on a separate sheet and accompanied by an application for commercial confidentiality under the provisions of the EP Regulations.

Part A

Permit Number	EPR/WP3231NB
Name of operator	Dairy Partners (Cymru Wales) Ltd
Location of Facility	Newcastle Emlyn
Time and date of the detection	12/05/2025

(a) Notification requirements for any activity that gives rise to an incident or accident which significantly affects or may significantly affect the environment

To be notified within 24 hours	
Date and time of the event	12/05/2025 approx 20:00
Reference or description of the location of the event	Watse Water Treatment Plant.
Description of where any release into the environment took place	Proximity of Crude Pit
Substances(s) potentially released	Dairy Wash down water
Best estimate of the quantity or rate of release of substances	100 – 150 litres
Measures taken, or intended to be taken, to stop any emission	Restarted the 3 crude pit pumps and clean any residue.
Description of the failure or accident.	At approx 20:00PM 12/05/2025 dairy partners experienced an externally induced power dip, this took out the 3 pumps that empty the crude pit which led to 100 – 150 litres of dairy wash down water entering the river. NRW officer Joseph Gallard attended site at 21:30 and took samples, this sample was then split with dairy partners.

(b) Notification requirements for the breach of a permit condition

To be notified within 24 hours unless otherwise specified below	
Emission point reference/ source	
Parameter(s)	

Limit	
Measured value and uncertainty	
Date and time of monitoring	
Measures taken, or intended to be taken, to stop the emission	

Time periods for notification following detection of a breach of a limit	
Parameter	Notification period

(c) In the event of a breach of permit condition which poses an immediate danger to human health or threatens to cause an immediate significant adverse effect on the environment:	
To be notified within 24 hours	
Description of where the effect on the environment was detected	
Substances(s) detected	
Concentrations of substances detected	
Date of monitoring/sampling	

Part B - to be submitted as soon as practicable

Any more accurate information on the matters for notification under Part A.	
Measures taken, or intended to be taken, to prevent a recurrence of the incident	
Measures taken, or intended to be taken, to rectify, limit or prevent any pollution of the environment which has been or may be caused by the emission	
The dates of any unauthorised emissions from the facility in the preceding 24 months.	

Name*	Ashton Daniels
Post	Operations Manager
Signature	<i>A. Daniels</i>
Date	12/05/2025

* authorised to sign on behalf of the operator