

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent AW1004901

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at PAINSCASTLE STW

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s):

Signed: **Dated:**

Name (block capitals): **Position:**



P1

Is discharge periodic or continuous ? Periodic [] Continuous [☒]

11

12

13

Discharge Consent Conditions :

Condition Name	Limit	Unit	Ind
DAILY VOL (DWF) M3/DAY	14.0	m3 ✓	
DISCHARGE RATE (L/S)	.5	l/sec ✓	
BOD 5 ATU	39.0	mg/l ✓	
SOLIDS SUSPENDED 105 C	60.0	mg/l ✓	

Other Details.

Note: If the discharge has changed in composition or volume since the consent was issued, please indicate the changes above.

If you wish future bills to be sent to a name and address other than that shown at the top of the previous page then please complete the details here.

Please give a contact name and telephone number here.

Signed :

J Adams pp J Lewis

Date:

17.5.91

NATIONAL RIVERS AUTHORITY

South Eastern Division

Roger Guy
Ieg Jones
P. Bulkrush
R. Morley

* * Variation of Consent * *

CONSENT CONSULTATION -- FISHERIES --- HYDROLOGY
CONSERVATION --- LAND DRAINAGE

Consent No: AW1004901 Grid Ref: 50 1710 4630 Date: 5.12.90

We have received an application to discharge.....Sewage Effluent
to.....Bach Howey.....at.....Painscastle Sewage Treatment works.

Daily Flow (Max/D.W.F.)

Powys

60 m³/day

COMMENTS


Please return to Pat Sainsbury within 14 days of the date at the top of the page. If no reply has been received by this date we will assume that you have no comment to make.

Applicant/Agent:

Address:

Welsh Water PLC
Plas-y-Ffynnon
Cambrian Way
Brecon
Powys

tel: 0874 3181



NATIONAL RIVERS AUTHORITY

WATER ACT 1989

Application for consent to discharge
Schedule 12



To:

The Consents Officer
National Rivers Authority
Welsh Region
Plas-yr-Afon/Rivers House
St. Mellons Business Park
Cardiff
CF3 0LT

Official Use Only
Dist/Area Ref. **South East**

Application No. **AW1001901.** (Review)

Date Received:
29-11-90.

PLEASE REFER TO THE ATTACHED NOTES WHEN COMPLETING THE APPLICATION

I/We hereby apply for consent under the provisions of the Water Act 1989 to make a discharge of effluent as described in this application and on the attached plan(s). I/We will bear the costs of any advertisement (see note 1).

I/We enclose a cheque for £ to cover the cost of this application (see note 2).

Signed *S. M. Lewis* Date *28-11-90*

Authorised on behalf of *DWR CYMRU CYF*

Have you made, or do you intend to make, an application to the Secretary of State for exemption from publicity? (See note 3.) **YES/NO***

Has this application been made in response to the service of a relevant prohibition? **YES/NO***

If yes please give reference number:

1a Full name and postal address of applicant. (See note 4.) Post Code: Daytime telephone number:	WELSH WATER PLC PLAS-Y-FFYNNON, CAMBRIAN WAY BRECON, POWYS. LD3 7HP 0874 3181
1b Agent (if any) Full name and postal address Contact name and daytime telephone number	Note: if this box is completed, all correspondence will be sent to this address.

NOTE: The application should be accompanied by 3 copies of an adequate plan and details of any environmental impact assessment. Failure to do so may result in a delay in processing the application. (See note 5.)

*Delete as necessary

2a) Address or other sufficient description of land or premises to which this application relates.	PAINCASTLE SEWAGE TREATMENT WORKS, POWYS.											
2b) National Grid Reference of point of discharge.	S.O	1710										
2c) District Council area.	4630											
3 State the nature of the discharge. Tick one or more boxes as appropriate. (See note 6.)	Sewage effluent ☒ Storm/emergency sewage effluent ☐ Trade effluent ☐ Any other matter ☐											
4 For sewage and trade effluent, and storm/emergency discharges, state:- a) Maximum quantity it is proposed to discharge in one day. (See note 7.) b) Highest rate at which it is proposed to operate the discharge. c) Periods during which the discharge will take place.	85 m³/day = 13.6 Sewage effluent 60 m³/day 0.7 l/sec CONTINUOUS											
5 For rainfall dependent discharges, state the area to be drained. (Roof areas and other impervious areas should be separately identified.)	m²											
6 Receiving medium Tick the category to which the proposed discharge(s) are to be made. <table border="0"> <tr> <td>A. TIDAL RIVER OR STREAM ☐</td> <td>E. INTO LAND ☐</td> </tr> <tr> <td>B. NON-TIDAL RIVER OR STREAM ☒</td> <td>F. ONTO LAND ☐</td> </tr> <tr> <td>C. CANAL ☐</td> <td>G. DIRECTLY INTO GROUNDWATER ☐</td> </tr> <tr> <td>D. LAKE, LOCH OR POND ☐ (not discharging to a river or stream)</td> <td>H. INTO LAND AND WATERCOURSE ☐</td> </tr> <tr> <td></td> <td>I. COASTAL WATER (See Note 8.) ☐</td> </tr> </table> If A-D or H, state name of watercourse, if known:- ACH HOWEY			A. TIDAL RIVER OR STREAM ☐	E. INTO LAND ☐	B. NON-TIDAL RIVER OR STREAM ☒	F. ONTO LAND ☐	C. CANAL ☐	G. DIRECTLY INTO GROUNDWATER ☐	D. LAKE, LOCH OR POND ☐ (not discharging to a river or stream)	H. INTO LAND AND WATERCOURSE ☐		I. COASTAL WATER (See Note 8.) ☐
A. TIDAL RIVER OR STREAM ☐	E. INTO LAND ☐											
B. NON-TIDAL RIVER OR STREAM ☒	F. ONTO LAND ☐											
C. CANAL ☐	G. DIRECTLY INTO GROUNDWATER ☐											
D. LAKE, LOCH OR POND ☐ (not discharging to a river or stream)	H. INTO LAND AND WATERCOURSE ☐											
	I. COASTAL WATER (See Note 8.) ☐											

- 7 The Authority will normally require adequate provision for the taking of samples of the discharge. Please indicate the means proposed. (See note 9.)

At the outlet ☒ At a manhole or sampling chamber ☐ See plan ☐ Other ☐

If other, please give further details:-

- 8 Indicate proposed means of discharge:-

1. Pipe ☒ 2. Channel ☐ 3. Borehole ☐
 4. Soakaway ☐ 5. Well ☐ 6. Sub-irrigation system ☐
 7. Culvert ☐ 8. Soakaway & sub-irrigation system ☐ 9. Other ☐

If 9 please give further details:-

- 9 Give details as appropriate

a) For pipes, channels, wells and boreholes, state diameter in millimetres or dimension(s) in metres.

a)

150 mm

b) For sub-irrigation systems, soakaway pits, wells and boreholes, state depth in metres and geological stratum, if known.

b)

c) For boreholes, state details of lining:

c)

Type of lining

Depth of lining

Depth of perforated lining

Depth of unperforated lining

: metres

: metres

: metres

- 10 Is there a foul sewer available to which the discharge could be made?

YES/NO*

If yes give reason for not connecting.

:

- 11 Give brief details of:

a) Source of water supply (eg mains, well, borehole, etc.)

a)

b) General purpose for which water is used (eg domestic, cooling, etc.)

b)

*Delete as necessary

12 Is consent required for a limited period? If yes give relevant dates	YES/NO*										
13 Does this proposal replace an existing discharge? If yes give details	YES/NO*										
14 Are there any existing consents for discharge from the premises? (see note 10) If yes, give details, numbers, if known.	YES/NO* Ref. A-100194 AW 1004901										
15 Please give details of the premises - tick as appropriate:- <table border="0" style="width: 100%;"> <tr> <td>1. Single dwelling ☐</td> <td>2. Multiple dwellings ☐</td> </tr> <tr> <td>3. Licenced premises ☐</td> <td>4. Vehicle parking area ☐</td> </tr> <tr> <td>5. Industrial premises ☐</td> <td>6. Fish farm ☐</td> </tr> <tr> <td>7. Mineral workings ☐</td> <td>8. WSPLC STW ☒</td> </tr> <tr> <td>9. Water supply ☐</td> <td>10. Other ☐</td> </tr> </table> If other, please give further details.		1. Single dwelling ☐	2. Multiple dwellings ☐	3. Licenced premises ☐	4. Vehicle parking area ☐	5. Industrial premises ☐	6. Fish farm ☐	7. Mineral workings ☐	8. WSPLC STW ☒	9. Water supply ☐	10. Other ☐
1. Single dwelling ☐	2. Multiple dwellings ☐										
3. Licenced premises ☐	4. Vehicle parking area ☐										
5. Industrial premises ☐	6. Fish farm ☐										
7. Mineral workings ☐	8. WSPLC STW ☒										
9. Water supply ☐	10. Other ☐										
16 IN THE CASE OF SUB-IRRIGATION SYSTEMS AND SOAKAWAYS											
a) Is any part of the system within 10 metres of the site boundary? b) Is any part of the systems within 10 metres of a watercourse? c) Is the land in which the disposal system is to be constructed, to be under-drained with land drains discharging to a watercourse? d) If the answer to either (b) or (c) is "YES" please state the name of the watercourse or sufficient information to identify it. e) Has a percolation test been carried out? If yes, please attach results.	YES/NO* YES/NO* YES/NO* YES/NO*										
17 FOR SEWAGE TREATMENT PLANTS											
a) State the population served/population equivalent/estimated population* b) Give details of the treatment plant to be used (see note 11)	*All year 85 *Summer *Winter SEPTIC TANK FILTER HUMUS TANK, SPREADERS										

FOR TRADE EFFLUENT AND SEWAGE DISCHARGES
CONTAINING TRADE EFFLUENT

18 a) Describe the trade effluent and the process(es) from which it arises. (See note 12.)

b) Maximum temperature of the effluent as discharged°C

c) Does the effluent contain any of the following? *~~YES~~/NO

If yes, underline those present and give full details (including maximum, minimum and mean values) separately.

- | | |
|---|--|
| 1. Mercury and its compounds | 24. Lead |
| 2. Cadmium and its compound | 25. Chromium |
| 3. Hexachlorocyclohexane
(lindane and related compounds) | 26. Zinc |
| 4. Carbon tetrachloride | 27. Copper |
| 5. DDT | 28. Nickel |
| 6. Pentachlorophenol (PCP) | 29. Arsenic |
| 7. Aldrin, dieldrin, endrin and isodrin | 30. Boron |
| 8. Hexachlorobenzene (HCB) | 31. Iron |
| 9. Hexachlorobutadiene (HCBD) | 32. Vanadium |
| 10. Chloroform | 33. PCSD's |
| 11. Polychlorinated biphenyls | 34. Cyfluthrin |
| 12. Dichlorvos | 35. Sulcofuron |
| 13. 1, 2-Dichloroethane | 36. Flucofuron |
| 14. Trichlorobenzene | 37. Permethrin |
| 15. Atrazine | 38. pH if outside the range 5.5 to 9.0 |
| 16. Simazine | 39. Cyanide |
| 17. Tributyltin compounds | 40. Azinphos-ethyl |
| 18. Triphenyltin compounds | 41. Fenthion |
| 19. Trifluralin | 42. Parathion |
| 20. Fenitrothion | 43. Parathion-methyl |
| 21. Azinphos-methyl | 44. Trichloroethylene |
| 22. Malathion | 45. Tetrachloroethylene |
| 23. Endosulfan | 46. Trichloroethane |
| | 47. Dioxins |

d) Give full details of any other significant chemical components contained in the effluent:—

19 FOR STORM AND EMERGENCY DISCHARGES AND SURFACE WATER SEWERS

State the type of discharge. Tick one or more boxes as appropriate.

Storm tanks	☐	Answer all except 23 & 26
Storm overflow from sewer	☐	Answer all except 23 & 26
Storm overflow from pumping station	☐	Answer all sections below
Emergency overflow from sewer	☐	Answer 20a, 21, 25, 27, 28
Emergency overflow from pumping station	☐	Answer all except 20b, 22
Surface Water	☐	Answer 20a
Other	☐	Answer as appropriate

If other, please give further details:-

20		
a) State dry weather flow to pumping station/in sewer	:	m ³ /day
b) State flow at which storm discharge will commence	:	l/sec
21 Expected frequency of operation	:	per annum
22 State volume of storm tank(s).	:	m ³
23 State volume of wet well	:	m ³
24 What provisions have been made to raise alarms? (eg telemetry)	:	
25 What facilities have been provided to prevent the discharge of gross solids? (For screens, give bar spacing or aperture.)	:	
26 What provisions have been included to deal with	:	
a) power failure?	:	
b) mechanical breakdown?	:	
c) rising main failure?	:	
27 What facilities have been provided for flow measurements?	:	
28 Are there any other factors to be taken into account?	:	

CONSENT VARIATION

RIVERS (CONTROL OF POLLUTION) ACTS 1951-1961

THE WATER AUTHORITIES (CONTROL OF DISCHARGES) ORDER 1978

AW1004901

I am directed by the Secretary of State for Wales to refer to the discharge consent in respect of the PAINSCASTLE... sewage treatment works dated 25. OCTOBER. 1971.

The Secretary of State for Wales, having consulted with the Welsh Water Authority, hereby gives notice that in exercise of his powers under Articles 4(8) and 8 of the Water Authorities (Control of Discharges) Order 1978 (SI 1978 No 1210), the conditions imposed on the said consent shall be varied in the following terms:

CONDITIONS

The quality and quantity of effluent shall not exceed the following maximum values:

Biochemical Oxygen Demand (+ ATU) over 5 days at 20°C; 39 milligrammes per litre.

Suspended Solids dried at 105°C; 60 milligrams per litre.

Ammoniacal ammonia expressed as nitrogen 1 milligrams per litre.

Dry Weather Flow ~~litres per second~~ or 41 metres cubed per day.

Maximum rate of flow 0.5 litres per second & 41 metres cubed per day.

This variation takes effect from the 20. January 1985.

This notice should be retained with the consent dated 25. OCTOBER. 1971.

George Roberts
WEP Division
Welsh Office

