

Pembroke PS. Hydrogen Plant  
Predicted Noise Levels - Rev 1

---

Report: Table of Results  
Model: Pembroke PS,Hydrogen Plant - Rev 2 [ISO Model with Greenlink]  
LAeq per octave: total results for receivers  
Group: (main group)  
Group Reduction: No

| Name     |   | Night  |       |    |    |     |     |     |      |      |      |      |
|----------|---|--------|-------|----|----|-----|-----|-----|------|------|------|------|
| Receiver | Description                               | Height | Total | 31 | 63 | 125 | 250 | 500 | 1000 | 2000 | 4000 | 8000 |
| RP1_A    | RP1 - Pwllcrochan                         | 1.50   | 41    | -- | 28 | 27  | 25  | 29  | 37   | 36   | 23   | -28  |
| RP2A_A   | RP2A - Greenhill Farm                     | 1.50   | 44    | -- | 31 | 31  | 30  | 37  | 40   | 36   | 23   | -16  |
| _A       | RP3. Lambeeth Farm                        | 1.50   | 29    | -- | 19 | 15  | 16  | 22  | 26   | 18   | -24  | --   |
| RP4*_A   | RP4*                                      | 1.50   | 38    | -- | 23 | 24  | 28  | 31  | 35   | 31   | 0    | --   |
| RP4A_A   | RP4A - Pennar Pont                        | 1.50   | 28    | -- | 19 | 14  | 16  | 20  | 26   | 16   | -38  | --   |
| _A       | RP5 - Moreston Cottage, Goldborough Road. | 1.50   | 26    | -- | 17 | 13  | 14  | 19  | 23   | 11   | -40  | --   |

All shown dB values are A-weighted