

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: JOHNSON & SWINGLER PARTNERS
THE DIRECTORS
LLANTEGLOS HAMLET LLANTEG
NEAR AMROTH
NARBERTH SA67 8PU

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent BN0044801

Nature of Discharge(s); SEWAGE EFF/TREATED EFF/CONTINUOUS
at

LLANTEGLOS HAMLET STW LLANTEG NEAR AMROTH NARBETH

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent:

Name:

Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):

Address:

Post Code:

Date of Transfer to new Holder(s);

Signed;

Dated;

Name (block capitals);

Position;





*Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru*

*National Rivers Authority
Welsh Region*

Messrs P Johnson & R H Swingler
Llanteglos Hamlet
Llanteg
Nr. Amroth
Narberth
Dyfed SA67 8PU

Enquiries: Norman Bunyan
DATE : 15 March 1994

Our Ref: 2/EQ/BN0044801/NB

Dear Sirs

RE: WATER RESOURCES ACT 1991 SECTION 88 SCHEDULE 10
REVIEW OF CONSENT TO DISCHARGE

Further to your application for the review of consent of the Authority to discharge under the provisions of Section 88 of the Water Resources Act 1991, I enclose the Authority's formal notice of the modifications made to the conditions of the consent to discharge sewage effluent from Llanteglos Hamlet STW, Llanteg, Dyfed.

Under the present Scheme of Charges for Discharges to Controlled Waters an annual charge will be made for all consents to discharge, except where the discharge is of sewage effluent of five cubic metres or less per day. This charge is based on information derived from the conditions attached to the consent to discharge, as outlined in the enclosed leaflet. A change in conditions may therefore result in a change in annual charge, you may therefore receive a revised bill in due course.

Where there is a change of ownership of the discharge, the Authority should be informed in writing in order that an apportioned charge may be raised.

If you are not satisfied with the new conditions of the consent you may appeal against the decision to the Secretary of State for Wales at the Welsh Office, Cathays Park, Cardiff CF1 3NQ.

Yours faithfully,

S J Brown
Area Environmental Quality Manager

Aelod Rhwydwrdd

Customer
Reference

DR 0586 7518 2GB

Dr John Stoner

Llys Afon
Hawthorn Rise
Hwlfordd
Dyfed SA61 2BQ
Ffôn: Hwlfordd (0437) 760081
Ffacs: (0437) 760881

Regional Board Member
Professor Ron Edwards

Regional General Manager
Dr John Stoner

Llys Afon
Hawthorn Rise
Haverfordwest
Dyfed SA61 2BQ
Tel: Haverfordwest (0437) 760081
Fax: (0437) 760881



Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru



NRA

National Rivers Authority
Welsh Region

Consent No.	BN0044801
-------------	-----------

WATER RESOURCES ACT 1991

Under Section 88 and Schedule 10 of the Water Resources Act 1991 and all other enabling powers the National Rivers Authority hereby serves this Notice

R E V I E W O F C O N S E N T

Page 1 of 2

To: Messrs P.Johnson and R.H Swingler.

Of: Llanteglos Hamlet, Llanteg, Nr Amroth, Narberth, Dyfed, SA67 8PU.

In respect of the previous Consent No. BN0044801 issued on : 14th December 1971.

For: A discharge of sewage effluent.

To: Land.

From: Llanteglos Hamlet STW, Llanteg, Nr Amroth, Narberth, Dyfed.

This Consent shall not be taken as providing a statutory defence against a charge of pollution in respect of any poisonous, noxious or polluting constituents not specified herein.

THE FOLLOWING REPLACE ALL PREVIOUS CONDITIONS.

1. The discharge shall consist only of biologically treated domestic sewage effluent from a sewage treatment works.
2. The discharge shall be made in the manner and at the place specified as follows:-

Discharging via: soakaway

Discharging to: land

At OS Grid Ref: SN 176 094.

As shown marked: Consent Point 'A' on the attached drawing/plan no. BN0044801.

3. Adequate facilities, approved in writing by the Authority, shall be provided to enable representative samples of the discharge to be safely and conveniently obtained at any time at the sewage treatment plant outlet as shown marked 'A' on the attached drawing/plan no. BN0044801.

Continued.....

Rheolwr Cyffredinol Rhanbarthol
Dr John Stoner
Llys Afon
Hawthorn Rise
Hwlfordd
Dyfed SA61 2BQ
Ffôn: Hwlfordd (0437) 760081
Ffacs: (0437) 760881

Regional General Manager
Dr John Stoner
Llys Afon
Hawthorn Rise
Haverfordwest
Dyfed SA61 2BQ
Tel: Haverfordwest (0437) 760081
Fax: (0437) 760881

WATER RESOURCES ACT 1991
Continuation Sheet

Consent No. BN0044801

Page 2 of 2

4. The maximum volume of effluent discharged shall not exceed 12 cubic metres per day.
5. The quality of the effluent discharged shall not be inferior to the following numerical limits.
 - i) The 5 day biochemical oxygen demand (BOD ATU), determined at 20 degrees Celsius after the suppression of nitrification using allyl thiourea, shall not exceed 50 milligrammes of Oxygen per litre of sample.
 - ii) The suspended solids concentration (dried at 105 degrees Celsius) shall not exceed 60 milligrammes per litre.
6. The treatment system must comply with Section 9 of BS 6297, (1983) and any subsequent amendments.
7. The soakaway must comply with Section 15 of BS 6297, (1983) and any subsequent amendments.
8. No part of the sub-surface soakaway system shall lie within 10 metres of the nearest watercourse.
9. The discharge shall not cause any adverse effects on sources of water used for public or private potable supply.
10. The treatment plant shall be operated and maintained in accordance with the manufacturer's instructions. In particular, the plant shall be desludged at sufficient frequency to prevent excessive solids carry over, normally at least once per year. When desludging, 10 to 15% of the accumulated sludge should be left in the tank, to aid biological breakdown.
11. The works shall be operated so as to prevent the effluent from causing ecological damage or from having any adverse aesthetic impact.

This Notice is given on: 28th March 1994 on behalf of the Authority
by: [Signature] Area Environmental Quality Manager

During the period ending with the 27th March 1996 the terms of this Notice will not be altered without the written agreement of the person making the discharge.

SOUTH WEST WALES RIVER AUTHORITY

RIVERS (PREVENTION OF POLLUTION) ACTS, 1951-1961

Consent to discharge of effluent

The South West Wales River Authority pursuant to the provisions of the above mentioned Acts, hereby consent to the construction of an outlet and to the discharge of effluent therefrom upon the following conditions:-

1. NAME AND ADDRESS OF PERSON to whom consent is given

Messrs. P. Johnson and R. Swinger,
Llanteglos, Llanteg, near Tenby, Pembs.

2. PREMISES to which consent relates

Holiday Bungalows at Llanteglos,
Llanteg, near Tenby, Pembs.

3. OUTLET

- (a) Location - situated on ~~right~~/left bank of ~~River~~ Summer Brook a tributary of the River
Map reference O.S. 2 $\frac{1}{2}$ " SN 10, Grid reference 176 094
(b) Construction - 6" diameter S.G.W. Pipe
(c) Use - restricted to Sewage/~~Sewage/Sewage/Sewage/Sewage~~Effluent produced at the above mentioned premises.

4. DISCHARGE

- (a) Nature Sewage effluent.
(b) Volume or rate of discharge 4,660 g.p.d. d.w.f.
Maximum rate of discharge 13,980 g.p.d. 3 x d.w.f.
(c) Temperature not to exceed 21 °C.
(d) Composition:-
(i) pH value not less than 6.0 or more than 8.5
(ii) Suspended solids not more than 10 p.p.m.
(iii) ~~Discharge of solids not more than 10 p.p.m.~~
(iv) 5 day B.O.D. at 20°C. not more than 10 p.p.m.
(v) ~~Discharge of B.O.D. not more than 10 p.p.m.~~
(vi) ~~Discharge of ammonia not more than 10 p.p.m.~~
(vii) ~~Discharge of effluent not more than 10 p.p.m.~~
(viii) Effluent shall not contain any other polluting substance or substances in concentrations toxic to fish and other animals.

(e) Sampling point to be located at point of outlet.

5. PERIOD OF CONSENT

The terms of this consent will not without the consent in writing of the person to whom this consent is given be altered before the expiration of the period ending with the 31st day of December, 1973.

Dated this 14th day of December 1971.

Clerk of the Authority.

Penyfai House,
Penyfai Lane,
LLANELLI,
Carns.

67
TO BE RETURNED TO THE
ENVIRONMENT AGENCY BY THE
NEW CONSENT HOLDER

1002 NR 9 Z



ASiantaeth YR
AMGYLCHEDD
ENVIRONMENT
AGENCY

Please complete parts A and B:

Regarding Discharge Consent Number: BN0044801 (essential information)

A. Confirmation of ~~New Holder~~/Joint Holders

Name ANTHONY AND JANE BARON
(Please use Block Capitals)

Address LLANTEGHOS ESTATE
LLANTEG, NR. AMROTH, Pembro.

Postcode SA67 8PU

Daytime Telephone Number (01834) 831677

(NB: Please duplicate or continue on a separate sheet if necessary for Joint Holders)

Date that you became responsible for the above consent 30/05/01

Signature of New Holder A. Baron Date 25/6/01

B. Confirmation of Bill Recipient Jane Baron

If the consent attracts an annual charge, who will be responsible for the bill?

Name ANTHONY AND JANE BARON
(Please use Block Capitals)

Address LLANTEGHOS ESTATE
LLANTEG, NR. AMROTH, Pembro.

Postcode SA67 8PU

Daytime Telephone Number (01834) 831677

Date that you became responsible for the above consent 30/05/01

Signature of bill recipient A. Baron Date 25/6/01

Please return to the Consents & Compliance Officer at the following address:

Environment Agency, Rivers House, St. Mellons Business Park, CARDIFF CF3 0LT.
Tel: 01222 770088 Fax: 01222 798555

CPD
updated
1-11-01

**I'W DYCHWELID I
ASiantaeth Yr Amgylchedd Gan
Ddeiliad Newydd Y Caniatâd**



**ASiantaeth Yr
AMGYLCHEDD
ENVIRONMENT
AGENCY**

Llenwch rannau A a B::

Ynglŷn â Chaniatâd Rhif: _____ (gwybodeth hanfodol)

A. Cadarnhad am y Deiliad/Cyd-Ddeiliaid Newydd

Enw _____

(Priflythrennau Bras)

Cyfeiriad _____

Cod Post _____

Rhif Teleffon Dydd _____

{DS: Gwnewch gopi o'r ddalen hon neu barhau ar ddalen ar wahân os bydd angen ar gyfer Deiliaid ar y Cyd}

Dyddiad y daethoch yn gyfrifol am y caniatâd uchod ____/____/____

Llofnod y Deiliad Newydd _____ Dyddiad ____/____/____

B. Cadarnhad am Dderbynnydd y Bil

Os oes tâl blyneddol am y caniatâd, pwy fydd yn gyfrifol am y bil?

Enw _____

(Priflythrennau Bras)

Cyfeiriad _____

Cod Post _____

Rhif Teleffon Dydd _____

Dyddiad y daethoch yn gyfrifol am y caniatâd uchod ____/____/____

Llofnod derbynnydd y bil _____ Dyddiad ____/____/____

Dychwelwch hon i'r Swyddog Caniatadau a Chydymffurfio yn y cyfeiriad canlynol:

Asiantaeth yr Amgylchedd, Plasyrâfon, Parc Busnes Llancirwg, Llancirwg, CAERDYDD CF3 0LT.
Tel: 01222 770088 Ffacs: 01222 798555