



*Awdurdod Afonydd Cenedlaethol
Rhanbarth Cymru*

*National Rivers Authority
Welsh Region*


CONSENT NO: CG03143-01

N.R.A. (WELSH REGION)

WATER ACT 1989 : SECTION 108, 113 AND SCHEDULE 12

CONSENT FOR A DISCHARGE

1. Welsh Water (hereinafter referred to as 'the Company' proposes to discharge biologically treated sewage effluent from the Capel Garmon Sewage Treatment, Conwy Valley, to Afon Conwy at National Grid Reference SH79975677 in accordance with the application dated 1st June 1990.
2. The proposal requires the consent of the National Rivers Authority in pursuance of sections 108, 113 and schedule 123 of the Water Act 1989.
3. The National Rivers Authority hereby consents to the proposed discharge subject to the discharge conforming at all times to the terms of the certificate attached hereto.


A.G. Dixon,
Divisional Scientist Nth.

Dated this 22nd day of November
1990

Signed on behalf of the
National Rivers Authority
(Welsh Region)



CG0314301_2006_03_06

Codeirrydd Rhanbarthol
Yr Athro Ron Edwards
Rheolwr Rhanbarth Cyffredinol
Dr John Stoner
Highfield, Ffordd Priestley
Caernarfon
Gwynedd, LL55 1HR
Ffôn: Caernarfon (0286) 672247
Ffacs: (0286) 4451

Regional Chairman
Professor Ron Edwards
Regional General Manager
Dr John Stoner
Highfield, Priestley Road
Caernarfon
Gwynedd, LL55 1HR
Tel: Caernarfon (0286) 672247
Fax: (0286) 4451

THE WATER ACT 1989
SECTIONS 108, 113 AND SCHEDULE 12

CERTIFICATE TO BE SUBMITTED WITH A REQUEST FOR A
DESCRIPTIVE DISCHARGE CONSENT

On behalf of Dwr Cymru cyf (hereinafter referred to as the Company) we certify that, in respect of the discharge from the Company's sewage treatment works at Capel Garmon, Conwy Valley(SH816553), which discharges to Afon Conwy at National Grid Reference.SH 79975677

1. The effluent derives from domestic sewage from a population of..200..... or less and contains no authorised trade waste.
2. There are no potable water supply intakes downstream which are likely to be adversely affected.
3. As far as is reasonably practicable, the works shall be operated so as to prevent:
 - i) Any matter being present in the effluent which will cause the receiving water to be poisonous or injurious to fish or to their spawn or spawning grounds or food or otherwise cause damage to the ecology of the receiving waters; and
 - ii) the treated effluent from having any adverse visual and other environmental impact.
4. The authority will operate the works having regard so far as is relevant, to the guidance set out in the National Water Council's Occasional Technical Paper Number 4, "The Operation and Maintenance of Small Sewage Works" dated January 1980. In particular the works shall be maintained properly such that:
 - a) it remains fully operational except at time of mechanical or electrical breakdown;
 - b) any such breakdowns shall be attended to promptly and the equipment returned to normal operation as soon as possible; and
 - c) tanks shall be desludged at sufficient frequency and in such a manner as to prevent problems with septic sludge, rising sludge for excessive carryover of suspended solids.

Signed *Thomas P. Woodward*
 (Name) *T.P. WOODWARD*
 Authorised signatory for the Company
 Dated this *TWENTY SECOND*
 Day of *NOVEMBER* 1990.

Water Resources Act 1991
as amended by the Environment Act 1995
Consent to Discharge
Certificate of Holder



**ENVIRONMENT
AGENCY**

Part A

To: DWR CYMRU CYFYNGEDIG
CONSENTS REGULATION OFFICER
PLAS-Y-FFYNNON
CAMBRIAN WAY
BRECON LD3 7HP

The **Environment Agency** ("the Agency") hereby confirm that the above named person is a/the registered holder of consent CG0314301

Nature of Discharge(s): SEWAGE EFF/TREATED EFF/CONTINUOUS
at
CAPEL GARMON STW COMBINED DISC

Note: This certificate should be kept with the consent document for future reference. If you transfer responsibility for the discharge to somebody else you must pass the consent to them and tell the Agency within 21 days. **Responsibility for the consent cannot be disclaimed by the holder but the registration of holder may be transferred to a successor.** To do this please complete the form below, then tear it off and return it to the address shown. If you fail to transfer the consent, even though you are no longer on the site, you may still be liable for prosecution for pollution. If you transfer the consent but do not tell us, you will be committing an offence. In case of any queries please contact your local Environment Agency office.

Part B Please complete in block capitals or type.

To:

Water Resources Act 1991: Notice of transfer of consent to discharge

Consent: **Name:**
Address:

I/We* hereby serve notice on the Agency that I/we* am/are* no longer a/the* Holder of the above consent which will be/was* transferred to:

* delete as appropriate

Name(s) of new holder(s):
Address:

Post Code:

Date of Transfer to new Holder(s);

Signed: **Dated:**

Name (block capitals): **Position:**

