

Compliance Assessment Report CAR_NRW0048547

Licence being assessed: WA/056/0063/006.

For: , held by Natural Resources Wales.

At: .

Type of assessment: Site Inspection, Reason: Routine.

On 03/06/2025, between 10:50 and 11:20.

Parts of licence assessed: All Permit

NRW Lead Officer: Gavin Summerhill.

Report sent to: John Rock, NRW Operations Manager, on 16/06/2025.

1. Summary of our findings (full details in section 4)

| Part of licenced activity assessed (criteria) | Assessment result | Licence condition |
|---|-------------------|-------------------|
| WR-G1 - Water Abstraction - Impoundment specified by licence - Inland water to be impounded | Assessed (A) | |
| WR-G2 - Water Abstraction - Impoundment specified by licence - Manner and extent of impoundment | Assessed (A) | |
| WR-G3 - Water Abstraction - Impoundment specified by licence - Point(s) of impoundment | Assessed (A) | |

Result types are explained in more detail in the 'Important Information' section below.

2. What action is required?

No action required.

3. What will happen next?

Any non-compliance we have identified and recorded on this form is an offence. It can result in criminal prosecution or civil sanctions being imposed depending on the circumstances of the offence.

At this time, we do not intend to take any further action.

This statement does not stop us from taking additional enforcement action if further relevant information comes to light or offences continue.

4. Details of our assessment


Site Report

On Tuesday 3rd June 2025 I carried out an inspection at Inland water (stream) known as Afon Ebwy Fach at Blaina, Abertillery. The permit is for a water resources impoundment licence. Permit Number WA/056/0063/006. I arrived on site at 10:50. The weather conditions were dry, warm and sunny. My Site inspection commenced at 10:55.

Observations

I proceeded to check the Upstream extent of recycled plastic traverse bar at National Grid Reference SO 20097 06843. I can confirm this was accurate (approximately) as stipulated by the permit. Please see fig 1 below.

Upstream extent of recycled plastic traverse bar (fig 1)



I continued to check the Downstream extent of recycled plastic traverse bar impoundment at National Grid Reference SO 20119 06718. I can confirm this was accurate (approximately) as stipulated by the permit. Please see fig 2 below.

Downstream extent of recycled plastic traverse bar (fig 2)



MANNER AND EXTENT OF IMPOUNDMENTS

To construct a rock ramp within the reinforced concrete channel consisting of twelve 500 millimetres high recycled plastic traverse bars and a 500 millimetre wide by 250 millimetre deep low flow notch.

I confirm this to be accurate as stipulated by the permit. Please see fig 3 and 4 below.

Rock ramp within the reinforced concrete channel (fig 3 and 4)



Breaches of permit condition:

- No breaches observed.

Action required by date specified:

- No actions required.

Contact details:

If you have any queries regarding this CAR form or to provide an update on any actions above, please contact me using the following details:

Gavin Summerhill (Environment Officer)

gavin.summerhill@cyfoethnaturiolcymru.gov.uk

If we do not receive the information requested within specified deadline and have not been informed as to why there is a delay, then we may serve a Regulation 60 Notice requiring the information under Environmental Permitting (England and Wales) Regulations 2016.

If you have any queries about this report, or to discuss completion of any actions, please contact the NRW Officer named above.

Important information

Legal status of this report

Your licence is issued to you under the Water Resources Act 1991 as amended by the Water Act 2003. You have a responsibility to comply with the conditions of your licence and prevent pollution/harm to the environment. You must also ensure that you comply with any other relevant legislation that may apply to your site's operations.

This report explains the findings of our assessment and any action you are required to take. We categorise non-compliance using our guidance for assessing non-compliance at regulated sites.

When we find potential non-compliance/s we will normally give you advice on how to maintain compliance.

To correct non-compliance, we may:

- require you to take specific actions
- issue a notice.

Any advice and guidance we give will be without prejudice to any other enforcement response that we consider may be required.

Assessment results and non-compliance categories (used in section 1):

| Assessment result | Description |
|-------------------|---|
| Assessed (A) | Assessed or assessed in part, no evidence of non-compliance found |
| Action only (X) | Action only relating to the activity assessment |
| Ongoing (O) | Ongoing non-compliance, not scored |

| Non-compliance category | Description |
|----------------------------|---|
| C1 Major | Potential to have a major, serious, persistent and/or extensive impact or effect on the environment, people and/or property |
| C2 Significant | Potential to have a significant impact or effect on the environment, people and/or property |
| C3 Minor | Potential to have a minor or minimal impact or effect on the environment, people and/or property |
| C4 No environmental impact | Non-compliance at a regulated site that cannot foreseeably have any impact on the environment, people and/or property |

If your assessment result in Section 1 is suspended, what does this mean?

In line with our guidance, we may suspend non-compliance for up to six months to allow time for remedial action to be taken. These will be re-instated if the action is not completed.

Full list of Water resource action criteria (used in section 1 and 2):**WR A: Abstraction specified by Licence**

- WR-A1 Source of supply
- WR-A2 Points of abstraction
- WR-A3 Means of abstraction
- WR-A4 Purposes of abstraction
- WR-A5 Period of abstraction
- WR-A6 Quantities
- WR-A7 Land
- WR-A8 Other specified on licence

WR B: Abstraction measurement and records

- WR-B1 Means of measurement
- WR-B2 Recording
- WR-B3 Reporting

WR C: Surface / Groundwater level and protected flow

- WR-C1 Minimum hands-off flow/level requirements
- WR-C2 Flow/level measurement devices
- WR-C3 Recording
- WR-C4 Reporting

WR D: Environmental monitoring and information

- WR-D1 Recording
- WR-D2 Reporting
- WR-D3 Notifications

WR E: Fish and eel passage

- WR-E1 Infrastructure specified by licence
- WR-E2 Maintenance and records

WR F: Discharge

- WR-F1 Point of discharge
- WR-F2 Infrastructure
- WR-F3 Measurement
- WR-F4 Recording
- WR-F5 Reporting

WR G: Impoundment specified by licence

- WR-G1 Inland water to be impounded
- WR-G2 Manner and extent of impoundment
- WR-G3 Point(s) of impoundment
- WR-G4 Construction and removal requirements
- WR-G5 Other specified on licence

WR H: Borehole infrastructure

- WR-H1 Infrastructure and accessibility
- WR-H2 Maintenance and calibration

Enforcement response

Any licence condition non-compliance is an offence and we may take legal action against you. Action we take can include prosecution or civil sanctions. See our Enforcement and Sanctions Guidance for further information.

Data protection notice

You should make sure that anyone named in this report knows that the information it contains will be processed by Natural Resources Wales to fulfil its regulatory and monitoring functions and to maintain the relevant public register(s).

We may also use and/or disclose the report in connection with:

- offering or providing you with our literature or services relating to environmental matters
- consulting with the public, public bodies and other organisations (e.g. Health and Safety Executive, local authorities) on environmental issues
- carrying out statistical analysis, research and development on environmental issues
- providing public register information to enquirers
- investigating possible breaches of environmental law
- assessing customer service satisfaction and improving our service
- Freedom of Information Act or Environmental Information Regulations requests.

We may also pass it on to our agents or representatives to do these things on our behalf.

Disclosure of information – this report will be available to view on-line

If you think this report contains commercially confidential information that should not be placed on our public register, you must contact your local Natural Resources Wales office within **fifteen working days** of receiving this report, using the contact details in the accompanying email or letter. You must give a full explanation of why it should not be added to our public register, including specifying which information is commercially confidential. We will assess your request and respond to you within 20 working days to let you know if we agree to your request.

What do I do if I disagree with the report or have a complaint?

If you disagree with this compliance assessment report, you should contact the lead officer without delay to discuss your concerns.

If you are unable to resolve the issue with the lead officer or their line manager you should contact our Customer Contact team on 0300 065 3000 (Mon to Fri 08:00 – 18:00), or email enquiries@naturalresourceswales.gov.uk for details of how to raise your dispute further through our Complaints and Commendations procedure.

If you are dissatisfied with our response, you can contact the Public Services Ombudsman for Wales by phone on 0300 7900203 or by email at ask@ombudsman.wales

Welsh Language Standards

We are committed to establishing Natural Resources Wales as a naturally bilingual organisation. We will provide compliance reports in your preferred language.